



Product Service

CERTIFICATE

No. Z10 15 03 62386 032

Holder of Certificate: Beckhoff Automation GmbH & Co. KG
Hülshorstweg 20
33415 Verl
GERMANY

Factory(ies): 62386

Certification Mark:



Product: Safety components

Model(s): EK 1914

Parameters:

| | |
|--------------------|---------------------|
| Supply voltage: | 24VDC (-15%...+20%) |
| Power dissipation: | 1,7W |
| Protection class: | IP20 |

Tested according to: DIN EN ISO 13849-1:2008 (Cat 4, PL e)
DIN EN 61000-6-2:2006
DIN EN 61000-6-4:2007

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: BV85712T

Valid until: 2020-03-03

Date, 2015-03-04

(Günter Greil)



Page 1 of 1