

CERTIFICATE


No. U8 07 04 62386 001

Holder of Certificate: **BECKHOFF Automation GmbH**

Eiserstraße 5
33415 Verl
GERMANY

Production Facility(ies): 62386

Certification Mark:



Product: **Controller (TwinSAFE)**

Model(s): **KL1904, KL2904, KL6904**

Parameters:

Supply voltage:	24 V DC
Power dissipation:	540 mW (KL1904), 2 W (KL2904; KL6904)

Tested according to:

- UL 508:1999
- CAN/CSA-C22.2 No. 142-M1987
- UL 1998:1998
- UL 991:2004

The product was voluntarily tested according to the relevant safety requirements and mentioned properties. It can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.: 028-71317113-000

Date, 2007-04-11

Page 1 of 1