



Product Service

CERTIFICATE

No. Z10 062386 0056 Rev. 01

Holder of Certificate: Beckhoff Automation GmbH & Co. KG
Hülshorstweg 20
33415 Verl
GERMANY

Certification Mark:



Product: Safety components
Model(s): EL2911

Parameters: Supply voltage: 24VDC (-15%/+20%)
Ambient temperature: -25°C...+55°C
Protection class: IP20

Tested according to: 2006/42/EC
EN 61508-1:2010 (SIL1-3)
EN 61508-2:2010 (SIL1-3)
EN 61508-3:2010 (SIL1-3)
EN IEC 62061:2021 (maximum SIL 3)
EN ISO 13849-1:2015 (Cat 4, PL e)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: BV99686C
Valid until: 2027-11-02

Date, 2022-11-03

(Peter Weiß)