InterBus Coupler BK4000

valid for all BK4xxx bus coupler

Technical Documentation

Version 1.3 2006-10-24

BECKHOFF

Contents

| ٦. | Foreword | 3 |
|----|--|--------|
| | Notes on the documentation | 3 |
| | Liability Conditions | 3 |
| | Delivery conditions | 3 |
| | Copyright | 3 |
| | Safety Instructions | 4 |
| | State at Delivery | 4 |
| | Description of safety symbols | 4 |
| 2. | Basic information | 5 |
| | The Beckhoff bus terminal system | 5 7 |
| | The interfaces | |
| | Power supply | 7 |
| | Power supply to the power contacts | 7 |
| | Power contacts | 7 |
| | Field bus connection Configuration interface | 7 8 |
| | K-bus contacts | 8 |
| | Supply isolation | 8 8 |
| | The operating modes of the bus coupler | 9 |
| | Mechanical construction | 10 |
| | Electrical data | 12 |
| | The peripheral data in the process image | 13 |
| | Starting operation and diagnostics | 16 |
| | ID code and ID length | 17 |
| | Run times and reaction times | 19 |
| 2 | | _ |
| ა. | InterBus coupler BK4000 in InterBus S | 21 |
| | Presentation of the system | 21 |
| | The medium: connector and cable | 21 |
| | Configuration of masters | 23 |
| 4. | Annex | 24 |
| | Example: combination of a process image in the bus coupler | 24 |
| | Representation of analog signals in the process image | 26 |
| 5. | Support and Service | 28 |
| | Beckhoff's branch offices and representatives | 28 |
| | Beckhoff Headquarters | 28 |
| | Beckhoff Support | 28 |
| | Beckhoff Service | 28 |

Foreword

Notes on the documentation

This description is only intended for the use of trained specialists in control and automation engineering who are familiar with the applicable national standards. It is essential that the following notes and explanations are followed when installing and commissioning these components.

Liability Conditions

The responsible staff must ensure that the application or use of the products described satisfy all the requirements for safety, including all the relevant laws, regulations, guidelines and standards.

The documentation has been prepared with care. The products described are, however, constantly under development. For that reason the documentation is not in every case checked for consistency with performance data, standards or other characteristics. None of the statements of this manual represents a guarantee (Garantie) in the meaning of § 443 BGB of the German Civil Code or a statement about the contractually expected fitness for a particular purpose in the meaning of § 434 par. 1 sentence 1 BGB. In the event that it contains technical or editorial errors, we retain the right to make alterations at any time and without warning. No claims for the modification of products that have already been supplied may be made on the basis of the data, diagrams and descriptions in this documentation.

Delivery conditions

In addition, the general delivery conditions of the company Beckhoff Automation GmbH apply.

Copyright

[©] This documentation is copyrighted. Any reproduction or third party use of this publication, whether in whole or in part, without the written permission of Beckhoff Automation GmbH, is forbidden.

Safety Instructions

State at Delivery

All the components are supplied in particular hardware and software configurations appropriate for the application. Modifications to hardware or software configurations other than those described in the documentation are not permitted, and nullify the liability of Beckhoff Automation GmbH.

Description of safety symbols

The following safety symbols are used in this documentation. They are intended to alert the reader to the associated safety instructions..



This symbol is intended to highlight risks for the life or health of personnel.

This symbol is intended to highlight risks for equipment, materials or the environment.

This symbol indicates information that contributes to better understanding.

Basic information

The Beckhoff bus terminal system

Up to 64 bus terminals

each with 2 I/O channels for any form of signal

The bus terminal system is the universal connecting link between a field-bus system and the sensor/actor level. A unit consists of a bus coupler, which is the interface to the fieldbus, and up to 64 electronic terminals, of which the last is an end terminal. Terminals, each with two I/O channels, are available for any form of technical signal and can be combined as desired. The various types of terminal are all constructed in the same way, so that the planning costs are kept extremely low. The height and depth of the construction are calculated for compact terminal cabinets.

Decentralized wiring of the I/O level

IPC as control unit

Fieldbus technology makes it possible to use compact control architectures. The I/O level does not need to be taken right up to the control unit. Sensors and actors can be connected decentrally with minimal lengths of cable. You can position the control unit at any convenient location in the installation. Using an industrial PC as control unit makes it possible to implement the operating and monitoring element as part of the control hardware, so the control unit can be located on an operating desk, control point or similar. The bus terminals constitute the decentralized input/output level of the control unit in the switch cabinet and its subordinate terminal cabinets. As well as the sensor/actor level, the power unit of the equipment is also controlled via the bus system. The bus terminal replaces a conventional terminal as the cabling level in the switch cabinet; the switch cabinet can be made smaller.

Bus couplers for all current bus systems

The Beckhoff bus terminal system combines the advantages of a bus system with the functionality of compact terminals. Bus terminals can be used on all current bus systems and serve to reduce the diversity of parts in the control unit, while behaving like the conventional standard units for the relevant bus system and supporting the entire range of functionality of the bus system.

Standard C rail assembly

The simple and compact assembly on a standard C rail, and the direct cabling of actors and sensors without cross connections between the terminals, serve to standardize the installation, as does the uniformly designed labeling.

The small size and great flexibility of the bus terminal system mean that you can use it anywhere that you could use a terminal and use any type of connection – analog, digital, serial or direct sensors.

Modularity

The modular construction of the terminal row, using bus terminals with various functions, limits the number of unused channels to at most one per function. Two channels to a terminal is the optimum solution for the number of unused channels and the cost per channel. The possibility of using power input terminals to provide separate power supplies also helps to minimize the number of unused channels.

Display of channel status

The integrated light-emitting diodes close to the sensor/actor indicate the status of each channel.

The K-bus

End terminal


The K-bus is the path taken by data within the terminal row. The bus coupler carries the K-bus through all the terminals by means of six contacts on the side walls of the terminals, and the end terminal terminates the K-bus. The user does not need to know anything about the function of the K-bus or the internal operation of terminals and bus couplers. There are numerous software tools available which provide for convenient planning, configuration and operation.

Power input terminals for separately powered groups

Three power contacts pass the operating power to the following terminals. You can use power input terminals to subdivide the terminal row as desired into groups, each with a separate power supply. These power input terminals are not taken into account for addressing the terminals, you can insert them at any position along the terminal row.

You can install up to 64 terminals on a terminal row, including power input terminals and the end terminal.

The principle of the bus terminal



Bus couplers for various fieldbus systems


You can use a variety of bus couplers to attach the electronic terminal row quickly and easily to the various fieldbus systems, and you can also subsequently convert to a different fieldbus system. The bus coupler deals with all the necessary monitoring and control tasks for operating the attached bus terminals, indeed all the operation and configuration of the bus terminals is carried out via the bus coupler. The fieldbus, K-bus and I/O level are electrically isolated.

If the exchange of data across the fieldbus is temporarily interrupted, logic states are preserved, digital outputs are cleared and analog outputs revert to a reset value which can be individually configured for each output when the equipment is set up.

The interfaces

There are six ways of making a connection to a bus coupler. These interfaces are designed as plug connections and spring terminals.

The InterBus-coupler BK4000



Power supply

24 V DC on the topmost terminals "24 V" and "0 V" The bus couplers need an operating power of 24 V DC which is connected via the topmost spring terminals, labeled "24 V" and "0 V". This power supply serves not only the electronic components of the bus coupler but (via the Kbus) also the bus terminals. The power supply of the bus coupler circuitry and that of the K-bus are electrically isolated from the voltage of the field level.

Power supply to the power contacts

Lower 3 terminal pairs for power input

maximum 24 V

maximum 10 A

The six lower connections with spring terminals can be used to supply power to the peripherals. The spring terminals are connected in pairs to the power contacts. The power supply to the power contacts has no connection to the power supply of the bus couplers. The power input is designed to permit voltages up to 24 V. The pair-wise arrangement and the electrical connection between the feed terminal contacts makes it possible to loop through the wires connecting to different terminal points. The load on the power contact may not continuously exceed 10 A. The current capacity between two spring terminals is the same as the capacity of the connecting wires.

Power contacts

Spring contacts at the side

On the right-hand side face of the bus coupler are three spring contacts which are the power connections. The spring contacts are recessed in slots to prevent them from being touched. When a bus terminal is connected, the blade contacts on the left-hand side of the bus terminal are connected to the spring contacts. The slot and key guides at the top and bottom of the bus couplers and bus terminals ensure reliable location of the power contacts.

Field bus connection

9 pin Sub-D female connector

There is a recessed front surface on the left-hand side. The typical Interbus connectors can be inserted here. You will find a detailed description of the 9 pin Sub-D male connector field bus interfaces in the Chapter entitled "The medium: connector and cable".

Configuration interface

Serial interface under the front flap

On the lower part of the front face you will find the standbus couplers which are fitted with an RS232 interface. The miniature plug can be attached to a PC by means of a connection cable and the configuration software KS2000. This interface enables you to configure the analog channels. You can also access the functionality of the configuration interface via the fieldbus by means of the PLC-Interface. The PLC interface consists of two additional bytes that are also inserted in the process data.

K-bus contacts

6 contacts at the side

The connections between the bus coupler and the bus terminals are effected by gold contacts at the right-hand side of the bus coupler. When the bus terminals are plugged together, these gold contacts automatically complete the connection to the bus terminals. The K-bus is responsible for the power supply to the electronic components of the K-bus in the bus terminals, and for the exchange of data between the bus coupler and the bus terminals. Part of the data exchange takes place via a ring structure within the K-bus. Disengaging the K-bus, for example by pulling on one the bus terminals, will break this circuit so that data can no longer be exchanged. However, there are mechanisms in place which enable the bus coupler to locate the interruption and report it.


Supply isolation

The bus couplers operate with three independent supplies. The input power supplies the electrically isolated K-bus circuitry in the bus coupler and the K-bus itself. The power supply is also used to generate the operating power for the fieldbus.

Note: All the bus terminals are electrically isolated from the K-bus, so that the K-bus is completely electrically isolated.

3 supply groups: fieldbus K-bus peripheral level


Setting up the power levels in the bus terminal system



The operating modes of the bus coupler

When it is first switched on the bus coupler carries out a self-test to check the functions of its components and the communications of the K-bus, and while this is going on the red I/O LED will flash. When the self-test has been completed successfully, the bus coupler will begin to test the attached bus terminals (the "bus terminal test") and read in the configuration from which it constructs an internal structure list, which is not accessible from outside. If an error occurs the bus coupler will enter the operating mode "STOP". If the start-up sequence is completed without errors the bus coupler will enter the mode "fieldbus start". The I/O RUN LED is lightening.

Start-up behavior of the bus coupler





After troubleshooting, the bus coupler can only be brought to the normal operating state by switching on again or by means of a field bus reset (triggered automatically by the master).

Mechanical construction

The Beckhoff bus terminal system is distinguished by its small volume and its high modularity. For project planning, one bus coupler and a number of bus terminals must be planned. The bus coupler's installation dimensions are independent of the field bus system. The total height of the housings may be exceeded if larger connectors are used, for example in the case of some high bus connectors for the InterBus.

Dimensions of a bus coupler





The overall width of the construction is the width of the bus coupler, including the bus end terminal, plus the width of the installed bus terminals. The bus terminals are 12 mm or 24 mm wide, depending on their function. Depending on the gauge of cables used the overall height of 68 mm may be overstepped by about 5 mm to 10 mm by the cables at the front.

Assembly and connections

It takes only a slight pressure to latch the bus coupler and the various bus terminals onto a supporting 35 mm C rail and a locking mechanism then prevents the individual housings from being removed. You can remove them without effort if you first release the latching mechanism by pulling the orange tab. You should carry out work on the bus terminals and the bus coupler only while they are switched off: if you plug or unplug components while the power is on you may briefly provoke some undefined state (and, for instance, reset the bus coupler).

You can attach up to 64 bus terminals in series on the right-hand side of the bus coupler. When you assemble the components, make sure that you mount the housings so that each slot comes together with the corresponding key. You cannot make any functional connections merely by pushing the housings together along the supporting track. When they are correctly mounted there should be no appreciable gap between the adjacent housings.

The right-hand side of a bus coupler is mechanically similar to a bus terminal. There are eight connections on the top which can be used to connect to thick-wire or thin-wire lines. The connection terminals are spring loaded. You open a spring terminal by applying a slight pressure with a screwdriver or other pointed tool in the opening above the terminal and you can then insert the wire into the terminal without any obstruction. When you release the pressure the terminal will automatically close and hold the wire secure-

ly and permanently.

The connection between bus couplers and bus terminals is automatically effected by latching the components together. The K-bus is responsible for passing data and power to the electronic components of the bus terminals. In the case of digital bus terminals, the field logic receives power via the power contacts. Latching the components together has the effect that the series of power contacts constitutes a continuous power track. Please refer to the circuit diagrams of the bus terminals: some bus terminals do not loop these power contacts through, or not completely (e.g. analog bus terminals or 4-channel digital bus terminals). Each power input terminal interrupts the series of power contacts and constitutes the beginning of a new track. The bus coupler can also be used to supply power to the power contacts.

Insulation test

The power contact labeled "PE" can be used as protective earth or ground. This contact stands proud for safety reasons and can carry short-circuit currents of up to 125A. Note that in the interests of electromagnetic compatibility the PE contacts are capacitively connected to the supporting track. This may lead to spurious results and even damage to the terminal when you test the insulation (e.g. insulation test for breakdown using a 230V mains supply to the PE line). You should therefore disconnect the PE line on the bus coupler while you carry out insulation tests. You can disconnect other power supply points for the duration of the test by drawing the power supply terminals out from the remaining row of terminals by at least 10mm. If you do this, there will be no need to disconnect the PE connections.

PE power contacts

The protective earth power contact ("PE") may not be used for any other connections.

Electrical data

The InterBus couplers differ by virtue of their capacity levels. The electrical data specific to the field bus is listed in this chapter. The following data differs depending on whether a standard or an economy variant is meant (BK4000, BK4500 and BK4010). Contrary to the standard variant, the economy variant limits the number of I/O points. Thus, there is no possibility of connecting inputs and outputs other than digital inputs and outputs.

| Technical data | InterBus-coupler BK4000/BK4500 | Economy -coupler BK4010 | |
|---|---|---|--|
| Power supply | 24 V, - 15% + 20% | , | |
| Input current | 105 mA typ. (30 digital inputs- / 20 outputs) 900 mA max. | 85 mA typ. 300 mA max. | |
| K-Bus output current | 1750 mA max. | 500 mA max. | |
| Potential isolation | 500 Vrms (K-bus / power supply to periphery) | | |
| Number of bus terminals | 64 including potential feed terminals and end termi | nal | |
| Digital peripheral signals | 256 inputs and outputs | 256 inputs and outputs | |
| Analog peripheral signals | 32 inputs and outputs#1 | | |
| Peripheral bytes | 64 input bytes and 64 output bytes | 32 input and 32 output bytes | |
| | | | |
| Configuration interface | available for KS2000 | | |
| Baud rates | 500 KBaud in conformity with the standard | | |
| | | | |
| Power contact voltage | 24V DC / AC | | |
| Power contact current load | 10 A | | |
| Dielectric strength 500 Vrms (Power contact / InterBus signal voltage), incoming interface | | , incoming interface | |
| Typical weight | 170g | | |
| Operating temperature 0 °C +55 °C | | | |
| Storage temperature | perature -20 °C +85 °C | | |
| Relative humidity | 95%, no condensation | | |
| Vibration / shock strength | in conformity with IEC 68-2-6 / IEC 68-2-27 | | |
| EMC strength,. Burst / ESD | in conformity with EN 61000-4-4/ EN 61000-4, limit EN 50082-2-4 | | |
| Installation position | any | | |
| Type of protection | IP20 | | |

K-Bus

Current consumption on the For operation of the K-Bus electronics, the bus terminals require power from the K-Bus which the bus coupler supplies. Refer to the catalog or the corresponding data sheets of the bus terminals for details of the current consumption of the K-Bus. At the same time, pay attention to the maximum output current of the bus coupler that is available for powering the bus terminals. By means of a special power supply terminal, an infeed into the K-Bus is possible at any point. Please consult Beckhhoff's technical support for details of how to use a power supply terminal.

The peripheral data in the process image

After power on, the bus coupler determines the configuration of the inserted input/output terminals. The bus coupler automatically assigns the affiliations between the physical slots of the input/output channels and the addresses of the process image.

The bus coupler generates an internal allocation list in which the input/output channels have a specific position in the process image. Here, a distinction is made according to inputs and outputs and according to bitoriented (digital) and byte-oriented (analog or complex) signal processing.

Two groups with only inputs or outputs each are formed. In one group, the byte-oriented channels are at the least significant address in ascending order. This block is followed by the bit-oriented channels.

Digital signals (bit-oriented)

Digital signals are bit-oriented. This means that one bit of the process image is assigned to each digital channel. The bus coupler sets up a block of memory containing the current input bits and arranges to immediately write out the bits from a second block of memory which belongs to the output channels.

The precise assignment of the input and output channels to the process image of the control unit is explained in detail in the Appendix by means of an example.

Analog signals (byte-oriented)

Processing of the analog signals is fundamentally byte-oriented. The analog input and output values are stored in the memory in a two-byte notation. The values are represented as "SIGNED INTEGER". The numeric value "0" stands for the input/output value "0V",0mA" or "4mA". In the default setting, the maximum value of the input/output value is represented by "7FFF" hex. The intermediate values are accordingly proportional with respect to one another. The area with a resolution of 15 bits is not realized with every input or output stage. In the event of an actual resolution of 12 bits, the last three bits are of no effect for outputs and, for inputs, they are read as "0". Each channel also has a control and status byte. The control and status byte is the most significant byte in the most significant word. An analog channel is represented with four bytes in the process image, three bytes of which are used. (In the BK3000 and BK4000, only two bytes are occupied for each analog channel in the process image of the corresponding bus system. The control and status bytes of the bus terminals can also be inserted by reconfiguration in the bus coupler and in the bus terminals.)

Special signals and interface

The BK4000 supports bus terminals with further interfaces such as RS232, RS485, incremental encoders or others. These signals can be controlled just like the above-mentioned analog signals. To some extent, a bit width of 16 does not suffice for the special signals. The bus coupler is capable of supporting any byte width. The effective byte length of the bus terminals can be preset with the KS2000 software.

Default assignment of inputs and outputs to the process image

When the bus coupler is first switched on it determines the number of attached bus terminals and sets up a list of assignments. This list distinguishes between analog channels and digital channels and between input and output; which are grouped separately. The assignments begin immediately to the left of the bus coupler. The software in the bus coupler creates the assignment list by collecting the entries for the individual channels one at a time, counting from left to right.

These assignments distinguish four groups:

| | Function type of the channel | Assignment level |
|----|------------------------------|----------------------|
| 1. | Analog outputs | byte-wise assignment |
| 2. | Digital outputs | bit-wise assignment |
| 3. | Analog inputs | byte-wise assignment |
| 4 | Digital inputs | bit-wise assignment |

Analog inputs/outputs are representative of other complex multi-byte signal bus terminals. The byte length of these terminals can be adjusted with the KS2000 software.

Overview of the breakdown of the process image in the bus coupler: The "x" variable represents the number of analog channels. By default, one channel has one word with 16 bits. The "y" variable represents the number of words with digital data. It is calculated on the basis of: $y = (integral\ result\ (number\ of\ digital\ channels\ /\ 16) + 1)$

Output data in the bus coupler


| A0 | |
|--------|--------------------|
| | byte-oriented data |
| Ax | |
| Ax+1 | |
| Δν⊥ν | bit-oriented data |

Input data in the bus coupler

| E0 | |
|----------------------|--------------------|
| | |
| | byte-oriented data |
| | |
| Ex | |
| _ , | |
| Ex+1 | |
| E X+1 | |
| Ex+1 | bit-oriented data |
| EX+1 | bit-oriented data |
| Ex+1 Ex+y | bit-oriented data |

The path from the I/Os to the process image in the InterBus The bus coupler automatically assigns the I/Os of the terminals to the process image in the Interbus protocol. The figure symbolically shows an allocation list. In special applications, the allocation list can be modified to suit requirements by using the KS2000 configuration software.

The allocation list in the master has the same effect. Byte-by-byte allocation is possible with the Phoenix Contact Firmware version 4.0 and higher. The master software CMD version 4.0 and higher is needed for this purpose. Setting via FB in the PLC is possible, but is not advisable owing to its great complexity.



Data consistency

Data is described as being consistent if its contents fit together. The following contents belong together:

- 1. the high and low bytes of an analog value (word consistency).
- 2. The control/status byte and the affiliated parameter word for access to the registers (e.g. 3-byte input/output for an analog channel).

In the interplay of the peripherals and the controller, data consistency is fundamentally initially only ensured for one byte (for most IBS masters, consistency exists for one word). That is to say, the bits of one byte are read in together or are ouput together. The InterBus transports all data of all inputs and outputs in one cycle. After an error-free transfer, the data is available for the controller. In practical terms, the master realises the "making available" by switching over from the old data block to the one that is now the current one. If the controller accesses the data area at the time of changeover, it reads a portion of the old data and a portion of the new data. As the controllers only access the memory word by word or even only byte by byte, the corresponding data consistency is produced. For processing of digital signals, byte consistency is sufficient. In cases when values with a length of more than 8 bits are transferred, e.g. in the case of analog values, the consistency must be extended. Attention must be paid to the correct method of acceptance by the controller of the consistent data from the bus system's master. Refer to the corresponding operating manual of the master system for a detailed description of the correct procedure.

Complex signal processing

All byte-oriented signal channels such as RS232, RS485 or incremental encoders partly operate with byte lengths of more than two bytes. With the exception of the length difference, handling of these is always comparable to that of analog signals.

Calculating the effective length

The greater number of inputs or outputs defines the effective length in the InterBus system. If the number of inputs and outputs does not correspond, remaining words are inserted in the process image as "blank words". These words are read with the contents "0000hex" and writing to these addresses has no effect (but the data is transferred and is stored in the bus coupler's memory).

Starting operation and diagnostics

After power-on, the bus coupler immediately checks the connected configuration. Error-free startup is signalled by extinguishing of the red "I/O ERR " LED. Flashing of the "I/O ERR" LED indicates an error in the area of the terminals. The error code can be determined by the frequency and quantity of flashing. This enables swift troubleshooting.

The diagnostic LEDs

The bus coupler has two groups of LEDs to provide a status indication. The top group with four LEDs indicates the status of the respective InterBus system. The meanings of the "Field bus status LEDs" are explained in the corresponding chapters of this manual. These correspond to the usual field bus displays.

There are two further green LEDs on the top right hand side of the bus coupler to indicate the supply voltage. The left LED indicates the 24V power supply of the bus coupler. The right LED signals the supply to the Power contacts.

Local errors

Two LEDs, the "I/O-LEDs", in the area under the aforementioned field bus status LEDs, serve to indicate the operating states of the bus terminals and connection to these bus terminals. The green LED lights up to indicate error-free operation. Error-free means that communication with the field bus system is also running without errors. To indicate errors, the red LED flashes at two different frequencies. Errors are coded in the flashing code as follows:

Flashing code

| fast flashing | Start of the error code |
|----------------------|-------------------------|
| first slow sequence | Error code |
| second slow sequence | Error argument |

Errors

| Error code | Error argument | Description |
|------------|----------------|--|
| 1 pulse | 0 1 2 | EEPROM checks on error Inline code buffer overflow Unknown data type |
| 2 pulses | 0 n (n > 0) | Programmed configuration Invalid table entry / bus coupler Table comparison (terminal n) invalid |
| 3 pulses | 0 | Terminal bus command error |
| 4 pulses | 0 n | Terminal bus data error Breakage after terminal n (0: coupler) |
| 5 pulses | n | Terminal bus error during register communication with terminal n |
| 6 pulses | 0 n (n > 0) | More than 32 words data width fitted on the bus coupler |

Error location

The number of pulses in the error segment indicates the position of the last bus terminal before the error. Passive bus terminals such as a supply terminal without diagnostics are not counted.

The bus coupler does not end the flashing sequence when the error is remedied. The bus coupler's operating state is still "Stop". The bus coupler can only be restarted by switching off and switching on the supply voltage.

It is only permitted to remove and instert bus terminals from the network in the deactivated state. The electronic circuitry of the bus terminals and of the bus coupler is largely protected against destruction, but malfunctions and damage cannot be ruled out when they are plugged together under voltage.

Field bus error

The top four LEDs indicate the operating states of InterBus communication. The bottom two LEDs indicate local communication between the bus coupler and bus terminals (as explained above).

Default setting Observe modification by KS2000 However, there is a relationship between the bottom green I/O RUN-LED and the field bus when the bus coupler is switched to the "SYNCHRO-NOUS" mode. Then the I/O RUN-LED only lights up in connection with access on the internal K-Bus. That is to say, the green I/O RUN-LED does not light up until data exchange via the field bus is commenced. This means that the field bus must access the bus coupler. This relationship does not apply in the bus coupler's default setting (FREERUN). In this state, the I/O RUN - LED is independent of the InterBus status.



The fieldbus status LEDs indicate the operating states of the field bus. The functions of the InterBus system are indicated by the "ready", "BA", "RC" and "RD" LEDs.

| The mean | ings of the l | EDs on the | BK4000 | | |
|----------|---------------|------------|--------|---|--|
| ready | ВА | RC | RD | Meaning | Remedy |
| lit | off | off | off | The bus coupler is ready | |
| lit | lit | lit | off | Remote bus active Data transfer with Master running | |
| lit | off | lit | off | Incoming field bus connection has been established, no connection | |
| lit | lit | off | lit | Continuing remote bus is off, owing to a cable fault or deactivated by the Master | Search for a cable discontinuity or a short-circuit of the master. |
| off | off | off | off | No function, power failure | |

The green I/O LED lights up in connection with access to the internal K-Bus. However, the bus coupler interrogates the configuration of the bus terminals after power on and does not perform a data exchange with the terminals. That is to say, the red I/O LED goes off after an error-free start up without the green I/O LED having to light up. The green I/O LED does not light up until data exchange is begun (see above).

ID code and ID length

ID code and ID length

In the ID cycle, which is run through to initialise the InterBus system, the connected stations inform each other of their functions and their byte lengths. After switching on, the InterBus coupler determines its length in the InterBus during the initialisation phases of the bus terminals and generates a corresponding ID code. The InterBus coupler reports as a digital or analog "external coupler" of variable length. The length results from the nature and number of fitted bus terminals.

Structure of the InterBus ID code


The InterBus ID code consists of 2 bytes. The MSB describes the length of the data words that are transferred. Bits 13, 14 and 15 can transfer messages. The LSB describes the type of the bus station in relation to the signal type and other features such as remote bus / peripheral bus station, PPC, ENCOM or DRIVECOM. The InterBus coupler BK4000 uses six IDs for inputs / outputs, inputs and outputs (x1hex, x2hex, x3hex). The IDs are

used depending on the type of the bus terminals, i.e. analog or digital (3xhex, 0xhex). These are the identifiers for remote bus stations from third-party manufacturers.

If there are analog and digital terminals on one BK4000, the bus coupler uses the analog identifier 3xhex. The following table shows an overview.

| Signal type | Signal direction | HEX-Value |
|-------------|------------------|-----------|
| Digital | INPUTS | 02 |
| Digital | OUTPUTS | 01 |
| Digital | INPUTS/OUTPUTS | 03 |
| Analog | INPUTS | 32 |
| Analog | OUTPUTS | 31 |
| Analog | INPUTS/OUTPUTS | 33 |

The length information is coded automatically from 0 to 32 words. A standard length of up to 9 words is supported by every bus master. The length up to 32 words is only supported from firmware version 3.2 and higher. Please pay attention to lengths greater than 10 words.



Depending on the configuration software for the InterBus master interfaces, the length and the ID code are entered separately or as a value in "16-bit hex format".

Most configuration programs permit reading of the actual configuratioan by the master. The following table shows the possibilities of the length code.

| Length of fitted periphery | Register width in the ID code |
|----------------------------|-------------------------------|
| 0 | 0 |
| 1 Word | 1 Word |
| 2 Words | 2 Words |
| 3 Words | 3 Words |
| 4 Words | 4 Words |
| 5 Words | 5 Words |
| 6 Words | 6 Words 1) |
| 7 Words | 7 Words 1) |
| 8 Words | 8 Words |
| 9 Words | 9 Words |
| 10 Words | 10 Words 1) |
| 11 - 12 Words | 12 Words 1) |
| 13 - 14 Words | 14 Words 1) |
| 15 - 16 Words | 16 Words 1) |
| 17 - 24 Words | 24 Words 1) |
| 25 - 32 Words | 32 Words 1) |

1) The data widths are only supported from Firmware version 3.20 and higher by the interfaces of the PLC and from driver version 2.0 by the PC card.

Remark:

In InterBus master interfaces with firmware versions less than 4.0, the peripheral data block of a bus coupler can only be placed in the process image as a coherent block with one base address. All following data of the block is assigned to the subsequent addresses.

Register expansion

The differing length of the bus coupler is realised by a rigister expansion. The number of additional registers is switched by the internal micro processor. The length is determined after power-on or after a reset and is written into a register expansion module as a numeric value. A change in the length is not possible without interrupting the exchange of data on the InterBus. The BK4000 must be restarted by means of a reset. The master must be reconfigured to the new length. In the auto configuration mode of some InterBus masters, the master starts even after the length of individual slaves has been modified if this does not result in any overlapping of addresses.

Run times and reaction times

Transfer of the signals from the input into the controller and from the controller to the outputs requires a run time. This is composed of various portions, i.e. transfer from the controller to the master; transfer via the InterBus and transfer from the bus coupler to the outputs. It applies conversly in the return direction.

Controller / master

Refer to the master manufacturer's data for details of the reaction time from the controller to the Master. The newly transferred data does not acquire validity until one cycle has been transferred completely.

TIBS =
$$(SW + (13 * (6 + N) + 1,5 * M) \times TBIT) * 2$$

SW = 0.2 ms

M = Number of bus couplers

N = Number of effective byte lengths

TBIT = 0.002 ms

Pay attention to the number of bytes and not the word length in the calculation of the times.

Note:

Pay attention to particular delays in the event of transmission errors. The InterBus requires 5 cycle times until the next valid data can be exchanged.

K-Bus reaction time

The reaction time on the K-Bus is determined by shifting / reading and saving of the data. The following table contains measured values for typical setups. It is possible to extrapolate to larger figures.

| Terminals fitted on the bus coupler Run time on the K-Bus | | | | |
|---|---------|------------|---------|--|
| Digital | Digital | Analog | T_cycle | |
| OŬT | IN | IN/OUT | (us) | |
| 4 | 0 | 0 | 150 | |
| 8 | 0 | 0 | 170 | |
| 12 | 0 | 0 | 170 | |
| 16 | 0 | 0 | 200 | |
| 20 | 0 | 0 | 200 | |
| 24 | 0 | 0 | 220 | |
| 28 | 0 | 0 | 220 | |
| 32 | 0 | 0 | 245 | |
| 0 | 4 | 0 | 150 | |
| 0 | 8 | 0 | 180 | |
| 0 | 12 | 0 | 180 | |
| 0 | 16 | 0 | 200 | |
| 0 | 20 | 0 | 200 | |
| 0 | 24 | 0 | 230 | |
| 0 | 28 | 0 | 230 | |
| 0 | 32 | 0 | 250 | |
| 4 | 4 | 0 | 170 | |
| 8 | 8 | 0 | 195 | |
| 12 | 12 | 0 | 220 | |
| 16 | 16 | 0 | 250 | |
| 20 | 20 | 0 | 275 | |
| 24 | 24 | 0 | 300 | |
| 28 | 28 | 0 | 325 | |
| 32 | 32 | 0 | 350 | |
| 4 | 4 | 1 (KL3202) | 630 | |
| 4 | 4 | 2 (KL3202) | 700 | |

InterBus coupler BK4000 in InterBus S

Presentation of the system

The InterBus system is structured as a data ring based on a central master/slave access method. It has the structure of a spacially distributed shift register. With its registers of differing length, each unit is part of this shift register ring, through which the master shifts the data serially.

Use of the ring structure offers the possibility of synchronous sending and receiving of data. The two data directions of the ring are accommodated in one cable.

Each station in the InterBus system has an ID register (identification register). This register contains information about the module type, the number of input and output registers and status and error states.

The InterBus system basically has two operating modes:

- The ID cycle, which is run through to initialise the InterBus system and whenever requested. In the ID cycle, the interface module reads the ID registers out of all devices on the bus system and builds up the process image on the basis of this information.
- The data cycle, the actual work cycle, which handles data transfer. In the data cycle, the input data from all devices is transferred out of the registers into the interface module and output data is transferred from the interface module to the devices.

System configurations and device types

The InterBus Club carries a large number of different ID codes. Except for 6 ID codes, these ID codes are used up for couplers of digital and analog peripherals from Phoenix Contact. Therefore, manufacturer identification via the ID code is not possible. (Refer to the chapter entitled "ID code and ID length" for detailed explanations). Handling of the InterBus BK4000 does not differ from the units from other manufacturers.

The medium: connector and cable

Remote bus connection

The InterBus distinguishes between the remote bus, the peripheral bus and the installation remote bus. The InterBus coupler is equipped with the remote bus interface. The Interbus coupler has an incoming and outgoing interface on the basis of a D-SUB connector and coupling.

Assignments on the connector and coupling of the remote bus cable

Outgoing remote bus, 9-pole D-SUB connector Cable

Incoming remote bus, 9-pole D-SUB coupling


| | | _ |
|-----|---|--------|
| /DO | 6 | green |
| DO | 1 | yellow |
| /DI | 7 | pink |
| DI | 2 | grey |
| COM | 3 | brown |
| | 5 | Jumper |
| | 9 | Jumper |

| 6 | /DO |
|---|-----|
| 1 | DO |
| 7 | /DI |
| 2 | DI |
| 3 | COM |

BK4500 InterBus Coupler and fibre optic connection

Fibre optic conductor: the InterBus Club elaborated the specification of a transmission technology based on fibre optic conductors for applications in highly interference-prone environments and also to increase the range. For the Beckhoff InterBus bus coupler with fibre optic connection (BK4500) use is made of F-SMA connectors and, in this case, the length between two stations is 1-40 m. Attention must be paid to ensuring that the slide switch for activating and deactivating the continuing interface is set to the corresponding position. If the BK4500 is the last InterBus station in the ring, the switch must be set to the OFF/END position. It must be set to the ON/NEXT position if the BK4500 is in a position in the ring.


BK4500



RS-422 transfer in accordance with the InterBus standard

| Fundamental characteristics | |
|-----------------------------|--|
| Network topology | Ring with integrated return line |
| Medium | Shielded twisted-pair cable, 3x twisted-pair with shield |
| Number of modules | 256 |
| between two stations | 400 m |
| Total length | 12.8 km |
| Data transfer rate | 500 Kbits/s |
| Connector | 9-Pin D-Sub plug connector and 9-pin D-Sub socket |

Wiring for InterBus



In systems with more than two modules, all modules are wired in succession. The ends of the bus cable must be terminated with resistors, which are located in each module. A jumper in the connector of the continuing interface signals to the bus coupler that a further modules follows.

To be able to realise uninterrupted operation, none of the connectors must be withdrawn and all modules in the ring must be operable.

Configuration of masters

As already explained above, the InterBus coupler creates a data area with input and output bytes. The affiliations between channels of the bus terminal and the bits and bytes of the process image are set by the bus coupler.

The InterBus master exchanges a coherent input and output data block with each InterBus coupler. The affiliations of the bytes from this data block to the addresses of the process image are established via data blocks of the PLC or the IBS SYS SWT or IBS CMD SWT G3 and G4 configuration software from Phoenix Contact. For other masters, use the manufacturer's corresponding tools.

Master configuration software

| Master / software | Configuration software | Manufacturer |
|-----------------------------|-------------------------------|-----------------|
| PLC-Interfaces versions < 4 | IBS SYS SWT IBS CMD SWT G3 | Phoenix Contact |
| PC interface version < 4 | IBS SYS SWT IBS CMD SWT G3 | Phoenix Contact |
| PLC-interfaces versions >4 | IBS CMD SWT G4 | Phoenix Contact |
| PC interfaces versions >4 | IBS CMD SWT G4 | Phoenix Contact |

Ensuring data consistency

Consistency of a station's data is ensured by the data transfer protocol of the InterBus. Consistency throughout the entire process image is ensured by sychronous sampling.

Asynchronous access by the controller's CPU (mostly PLC) to the data area of the InterBus master may lead to inconsistencies. Most InterBus masters ensure access to 16-bit words and, to some extent, also to 32-bit double words. Please refer to the corresponding manufacturer's manuals for further details of special access methods relating to the master interfaces.

The S5 modules IBS S5 DCB and IBS S5 DSC as InterBus masters are common PLC interfaces.

The masters featuring firmware version 4.0 are particularly convenient to operate. The CMD configuration software allows users to define the settings under Windows. Byte-by-byte and also bit-by-bit allocation of the peripheral data in the controller's address area is possible. Data consistencies can be selected in groups.

Conformity with the InterBus standard The BK4xxx operate with the SUPI 3 (Serial Universal Peripheral Interface) protocol chip. The SUPI 3 protocol chip handles the complete InterBus protocol. In comparison with the predecessor versions (SUPI 2), the SUPI 3 offers extended diagnostic and error management. Please refer to the manuals of the Interbus masters used for details of the supported functionalities of the SUPI 3 chips.

Annex

Example: combination of a process image in the bus coupler

An example explains the affiliations of the input and output channels to the process image. Our example setup should consist of the following bus terminal modules:

In this configuration, the bus coupler creates the allocation list that follows below

| Position | Function module on the busbar |
|----------|-------------------------------|
| POS00 | Bus coupler |
| POS01 | Digital inputs, 2 channels |
| POS02 | Digital inputs, 2 channels |
| POS03 | Digital inputs, 2 channels |
| POS04 | Digital inputs, 2 channels |
| POS05 | Digital inputs, 2 channels |
| POS06 | Digital inputs, 2 channels |
| POS07 | Digital outputs, 2 channels |
| POS08 | Digital outputs, 2 channels |
| POS09 | Digital outputs, 2 channels |
| POS10 | Analog inputs, 2 channels |
| POS11 | Analog outputs, 2 channels |
| POS12 | Analog outputs, 2 channels |
| POS13 | Analog inputs, 2 channels |
| POS14 | Infeed terminal |
| POS15 | Digital inputs, 2 channels |
| POS16 | Digital inputs, 2 channels |
| POS17 | Digital inputs, 2 channels |
| POS18 | Digital outputs, 2 channels |
| POS19 | Digital outputs, 2 channels |
| POS20 | Analog outputs, 2 channels |
| POS21 | End terminal |

By default, InterBus, DeviceNet and Profibus couplers only map signal channels of 16-bits width. The CONTROL/STATUS BYTE is not available. That is to say, an analog input terminal with 2 channels, for example, appears in the process image with 2 x 16 bits. The figures showing the byte addresses and the affiliations differ correspondingly when CONTROL/STATUS is activated.

Part for byte-oriented data, analog outputs

| relative byte address | Bit position | Process image in the controller | Position in the block |
|--------------------------|--------------|---------------------------------|-----------------------|
| 0, 1 | none | A0, A1 | POS11 |
| 2, 3 | none | A2, A3 | POS11 |
| 4, 5 | none | A4, A5 | POS12 |
| 6, 7, | none | A6, A7 | POS12 |
| 8, 9 | none | A8, A9 | POS20 |
| 10, 11 | none | A10, A11 | POS20 |

Part for bit-oriented, data, digital outputs

| relative byte address | Bit position | Process image in the controller | Position in the block |
|-----------------------|--------------|---------------------------------|-----------------------|
| 12 | 0 | A12 | POS07 |
| 12 | 1 | A12 | POS07 |
| 12 | 2 | A12 | POS08 |
| 12 | 3 | A12 | POS08 |
| 12 | 4 | A12 | POS09 |
| 12 | 5 | A12 | POS09 |
| 12 | 6 | A12 | POS18 |
| 12 | 7 | A12 | POS18 |
| 13 | 0 | A13 | POS19 |
| 13 | 1 | A13 | POS19 |

Part for byte-oriented data, analog inputs

| relative byte address | Bit position | Process image in the controller | Position in the block |
|-----------------------|--------------|---------------------------------|-----------------------|
| 0, 1 | none | E0, E1 | POS10 |
| 2, 3 | none | E2, E3 | POS10 |
| 4, 5 | none | E4, E5 | POS13 |
| 6, 7 | none | E6, E7 | POS13 |


Part for bit-oriented data, digital input

| relative byte address | Bit position | Process impage in the controller | Position in the block |
|-----------------------|--------------|----------------------------------|-----------------------|
| 8 | 0 | E8 | POS01 |
| 8 | 1 | E8 | POS01 |
| 8 | 2 | E8 | POS02 |
| 8 | 3 | E8 | POS02 |
| 8 | 4 | E8 | POS03 |
| 8 | 5 | E8 | POS03 |
| 8 | 6 | E8 | POS04 |
| 8 | 7 | E8 | POS04 |
| 9 | 0 | E9 | POS05 |
| 9 | 1 | E9 | POS05 |
| 9 | 2 | E9 | POS06 |
| 9 | 3 | E9 | POS06 |
| 9 | 4 | E9 | POS15 |
| 9 | 5 | E9 | POS15 |
| 9 | 6 | E9 | POS16 |
| 9 | 7 | E9 | POS16 |
| 10 | 0 | E10 | POS17 |
| 10 | 1 | E10 | POS17 |


Positions POS14 and POS21 are not relevant with regard to data transfer. They do not appear in the list. If a byte is not used completely, e.g. E8, the bus coupler pads the remaining bits of the byte with zeros.

Overview of the process image breakdown in the bus coupler:

Output data in the bus coupler



Input data in the bus coupler



The base addresses E0 and A0 listed here apply as relative addresses or addresses in the bus coupler. In the bus master software, a base peripheral address may be assigned to the base address of the bus coupler. All following addresses are automatically assigned the successive addresses depending on the length of the actual data words.

Firmware version 4.0 and higher of the InterBus interfaces:

The bus master may place the addresses in a freely chosen location in the controller's process image. The masters's configuration software enables any chosen assignment of the bytes to the addresses of the process image in the controller.

Representation of analog signals in the process image

Each analog channel consists of three input bytes and three output bytes. In the standard case, however, an analog channel only requires one data word in the process image. These two bytes represent the value as a signed integer, i.e. 15 bits with sign. The data format is used regardless of the actual resolution. For example: in the case of a resolution of 12 bits, the four least significant bits are of no relevance. By means of the KS2000 configuration software, the third byte can be inserted in the process image for any channels. The least significant byte has control and status functons. Various operating modes can be set with the control byte. The six least significant bits can be used as addressing bits. Addressing serves to read and write a register set. The register set has 64 registers and allows setting of different operating parameters, for example selection of a thermocouple type or representation of a value in a different numerica format.


I/O bytes of an analog channel in the process image

| Output byte 1 | Output byte 0 | Control byte |
|---------------|---------------|--------------|
| | | |
| Input byte 1 | Input byte 0 | Status byte |

Significance of the control/status byte for access to the register model

| BIT 7 | 0 = NORMALMODE, | 1 = CONTROL MODE |
|-------|-----------------------|------------------|
| BIT 6 | 0 = READ, | 1 = WRITE |
| BIT 5 | Register address, MSB | |
| BIT 4 | Register address | |
| BIT 3 | Register address | |
| BIT 2 | Register address | |
| BIT 1 | Register address | |
| BIT 0 | Register address, LSB | |

Register set of an analog channel



Auxiliary process image

This representation is not accessible in the bus coupler's default. The KS2000 software is needed.

The meanings of the registers and of the status bytes are explained in the bus terminal's corresponding data sheets. As far as its structure is concerned, the module is identical for all bus terminals that enable more extensive signal processing.

Support and Service

Beckhoff and their partners around the world offer comprehensive support and service, making available fast and competent assistance with all questions related to Beckhoff products and system solutions.

Beckhoff's branch offices and representatives

Please contact your Beckhoff branch office or representative for local support and service on Beckhoff products!

The addresses of Beckhoff's branch offices and representatives round the world can be found on her internet pages: http://www.beckhoff.com

You will also find further documentation for Beckhoff components there.

Beckhoff Headquarters

Beckhoff Automation GmbH Eiserstr. 5

33415 Verl Germany

phone: + 49 (0) 5246/963-0 fax: + 49 (0) 5246/963-198 e-mail: info@beckhoff.com web: www.beckhoff.com

Beckhoff Support

Support offers you comprehensive technical assistance, helping you no only with the application of individual Beckhoff products, but also with other, wide-ranging services:

- support
- · design, programming and commissioning of complex automation systems
- and extensive training program for Beckhoff system components

hotline: + 49 (0) 5246/963-157 fax: + 49 (0) 5246/963-9157 e-mail: support@beckhoff.com

Beckhoff Service

The Beckhoff Service Center supports you in all matters of after-sales service:

- on-site service
- repair service
- spare parts servive
- · hotline service

hotline: + 49 (0) 5246/963-460 fax: + 49 (0) 5246/963-479 e-mail: service@beckhoff.com