

|    |  |
|----|--|
| EN | <b>PS9771-2440-0000 Installation Manual</b>      |
| DE | <b>PS9771-2440-0000 Installationsanleitung</b>   |
| FR | <b>PS9771-2440-0000 Manuel d'installation</b>    |
| ES | <b>PS9771-2440-0000 Manual de instalación</b>    |
| IT | <b>PS9771-2440-0000 Manuale di Installazione</b> |
| PT | <b>PS9771-2440-0000 Manual de instalação</b>     |

|  |
|--|
| <b>DC/DC Converter 475-750V/24V, 40A, 960W</b> |
| <b>DC/DC-Wandler 475-750V/24V, 40A, 960W</b>   |
| <b>Convertisseur 475-750V/24V, 40A, 960W</b>   |
| <b>Convertidor 475-750V/24V, 40A, 960W</b>     |
| <b>Convertitore 475-750V/24V, 40A, 960W</b>    |
| <b>Conversor 475-750V/24V, 40A, 960W</b>       |

Doc. ID: PU-414.015.25-xxA (2021-10-27-MW2)

**Read this first!****English**

Before operating this device, please read this manual thoroughly and retain this manual for future reference! This device may only be installed and put into operation by qualified personnel. If damage or malfunction should occur during operation, immediately turn power off and send device to the factory for inspection. The device does not contain serviceable parts. The information presented in this document is believed to be accurate and reliable and may change without notice. For any clarifications the English translation will be used.

**WARNING****Risk of electrical shock, fire, personal injury, or death:**

- Turn power off before working on the device. Protect against inadvertent re-powering.
- Do not open, modify or repair the device.
- Use caution to prevent any foreign objects from entering the housing.
- Do not use in wet locations or in areas where moisture or condensation can be expected.
- Do not touch during power-on and immediately after power-off. Hot surfaces may cause burns.

**A lire avant mise sous tension!****Français**

Veuillez lire ces instructions de montage et d'entretien avant de mettre l'alimentation sous tension. Conservez ce manuel qui vous sera toujours utile. Cette alimentation ne doit être installée que par du personnel qualifié et compétent. En cas de dommage ou dysfonctionnement, coupez immédiatement la tension d'alimentation et retournez l'appareil à l'usine pour vérification ! L'alimentation ne contient pas de pièces échangeables Les données indiquées dans ce document servent uniquement à donner une description du produit et n'ont aucune valeur juridique. En cas de divergences, le texte anglais fait foi.

**AVERTISSEMENT****Prendre en compte les points suivants, afin d'éviter toute détérioration électrique, incendie, dommage aux personnes ou mort:**

- Mettre l'alimentation hors tension avant toute intervention sur celle-ci et s'assurer qu'il n'y a pas risque de redémarrage.
- Ne pas ouvrir, modifier ou réparer l'alimentation.
- Veiller à ce qu'aucun objet ne rentre en contact avec l'intérieur de l'alimentation (trombones, pièces métalliques).
- Ne pas faire fonctionner l'appareil dans un environnement humide ou dans un environnement où il peut y avoir de la condensation.
- Ne pas toucher le carter pendant le fonctionnement ou directement après la mise hors tension. Surface chaude risquant d'entraîner des blessures.

**Leggere prima questa parte!****Italiano**

Prima di collegare il sistema di alimentazione elettrica si prega di leggere attentamente le seguenti avvertenze. Conservare le istruzioni per la consultazione futura. Il sistema di alimentazione elettrica deve essere installato solo da personale competente e qualificato. Se durante il funzionamento si verificano anomalie o guasti, scollegare immediatamente la tensione di alimentazione. In entrambi i casi è necessario far controllare l'apparecchio dal produttore! I dati sono indicati solo a scopo descrittivo del prodotto e non vanno considerati come caratteristiche garanziate dell'apparecchio. In caso di differenze o problemi è valido il testo inglese

**AVVERTENZA****Il mancato rispetto delle seguenti norme può provocare folgorazione elettrica, incendi, gravi incidenti e perfino la morte:**

- Prima di eseguire interventi di installazione, di manutenzione o di modifica scollegare la tensione di rete ed adottare tutti i provvedimenti necessari per impedire il ricollegamento non intenzionale.
- Non tentare di aprire, di modificare o di riparare da soli l'apparecchio.
- Impedire la penetrazione di corpi estranei nell'apparecchio, ad esempio fermagli o altri oggetti metallici.
- Non far funzionare l'apparecchio in un ambiente umido. Non far funzionare l'apparecchio in un ambiente soggetto alla formazione di condensa o di rugiada.
- Non toccare quando acceso e subito dopo lo spegnimento. La superficie calda può causare scottature.

**Vor Inbetriebnahme lesen!****Deutsch**

Bitte lesen Sie diese Warnungen und Hinweise sorgfältig durch, bevor Sie das Gerät in Betrieb nehmen. Bewahren Sie die Anleitung zum Nachlesen auf. Das Gerät darf nur durch fachkundiges und qualifiziertes Personal installiert werden. Bei Funktionsstörungen oder Beschädigungen schalten Sie sofort die Versorgungsspannung ab und senden das Gerät zur Überprüfung ins Werk. Das Gerät beinhaltet keine Servicebauteile. Die angegebenen Daten dienen allein der Produktbeschreibung und sind nicht als zugesicherte Eigenschaften im Rechtssinne aufzufassen. Im Zweifelsfall gilt der englische Text.

**WARNUNG****Missachtung nachfolgender Punkte kann einen elektrischen Schlag, Brände, schwere Unfälle oder Tod zur Folge haben:**

- Schalten Sie die Eingangsspannung vor Installations-, Wartungs- oder Änderungsarbeiten ab und sichern Sie diese gegen unbeabsichtigtes Wiedereinschalten.
- Führen Sie keine Änderungen oder Reparaturversuche am Gerät durch. Gerät nicht öffnen!
- Verhindern Sie das Eindringen von Fremdkörpern, wie z.B. Büroklammern und Metalleilen.
- Betreiben Sie das Gerät nicht in feuchter Umgebung oder in einer Umgebung, bei der mit Betaubung oder Kondensat zu rechnen ist.
- Gehäuse nicht während des Betriebes oder kurz nach dem Abschalten berühren. Heiße Oberflächen können Verletzungen verursachen.

**Lea primero!****Español**

Conserve este manual como referencia para futuras consultas. La fuente de alimentación solo puede ser instalada y puesta en funcionamiento por personal cualificado. Por favor lea detenidamente este manual antes de conectar la fuente de alimentación. Si se produce un fallo o mal funcionamiento durante la operación, desconecte inmediatamente la tensión de alimentación. En ambos casos, el equipo debe ser inspeccionado en fábrica. La información presentada en este documento es exacta y fiable en cuanto a la descripción del producto y puede cambiar sin aviso. En caso de duda, prevalece el texto inglés.

**ADVERTENCIA****Riesgo de descarga eléctrica, incendio, accidente grave o muerte:**

- Desconectar la tensión de red antes de trabajar en la fuente de alimentación. Evite una posible reconexión involuntaria.
- No realizar ninguna modificación o reparación de la unidad. No abrir la unidad.
- Evitar la introducción en la carcasa de objetos extraños.
- No usar el equipo en ambientes húmedos. No operar el equipo en ambientes donde se espere la formación de rocío o condensación.
- No tocar durante el funcionamiento ni inmediatamente después del apagado. El calor de la superficie puede causar quemaduras graves.

**Leia primeiro!****Português**

Recomendamos a leitura cuidadosa das seguintes advertências e observações, antes de colocar em funcionamento a fonte de alimentação. Guarde as Instruções para futura consulta, em casos de dúvida. A fonte de alimentação deverá ser instalada apenas por profissionais da área, tecnicamente qualificados. Se por acaso, durante a utilização ocorrer algum defeito de funcionamento ou dano, desligue imediatamente a tensão de alimentação. Em ambos os casos, será necessária uma verificação na Fábrica! Os dados mencionados têm como finalidade somente a descrição do produto, e não devem ser interpretados como propriedades garantidas no sentido jurídico. Em caso de dúvidas aplique-se o texto em inglês.

**ATENÇÃO****A não observância ou o incumprimento dos pontos a seguir mencionados, poderá causar uma descarga elétrica, incêndios, acidentes graves ou morte:**

- Antes de trabalhos de instalação, manutenção ou modificação, desligue a tensão de alimentação, protegendo-a contra uma nova ligação involuntária.
- Não efectue nenhuma modificação ou tentativa de reparação no aparelho. Quando necessário contacte o seu distribuidor. Não abra o aparelho.
- Proteger a fonte de alimentação contra a introdução inadvertida de corpos metálicos, como por ex., cliques ou outras peças de metal.
- Não usar o aparelho em ambientes húmedos. Não usar o aparelho em ambientes propensos a condensações.
- Não tocar enquanto estiver em funcionamento, nem após a desligar. A superfície poderá estar quente e provocar lesões.

## Product Description

The PS9771-2440-0000 is a DIN-rail mountable DC/DC converter, which provides a floating, stabilized and galvanically separated SELV/PELV output voltage.

## Intended Use

This device is designed for installation in an enclosure and is intended for commercial use, such as in industrial control, process control, monitoring and measurement equipment or the like.

Do not use this device in equipment where malfunction may cause severe personal injury or threaten human life. If this device is used in a manner outside of its specification, the protection provided by the device may be impaired. The device is designed for industrial environments. Do not use in residential, commercial and light-industrial environments.

## Installation Instructions

Install device in an enclosure providing protection against electrical, mechanical and fire hazards.

Install the device onto a DIN-rail according to EN 60715 with the input terminals on the bottom of the device.

Make sure that the wiring is correct by following all local and national codes. Use appropriate copper cables that are designed for a minimum operating temperature of 60°C for ambient temperatures up to +45°C, 75°C for ambient temperatures up to +60°C and 90°C for ambient temperatures up to +70°C. Ensure that all strands of a stranded wire enter the terminal connection. Unused screw terminals should be securely tightened.

The device is designed for pollution degree 2 areas in controlled environments. No condensation or frost is allowed.

The enclosure of the device provides a degree of protection of IP20. The enclosure does not provide protection against spilled liquids.

The isolation of the devices is designed to withstand impulse voltages up to 4kV according to IEC 60664-1.

The device is designed as "Class of Protection I" equipment according to IEC 61140. Do not use without a proper PE (Protective Earth) connection.

The device is designed to be supplied from a DC (input) voltage derived from a 3-phase TN, TT, IT or Corner grounded delta mains supply systems by means of a B6 bridge rectifier.

The input can also be supplied by batteries or similar DC sources. Since the continuous voltage between the input voltage and the PE/earth potential must not exceed 480V r.m.s., the input voltage must be grounded at about half the supply voltage as shown in option 2 in "Wiring Scheme".

Do not ground the positive or negative input voltage pole. Follow the wiring scheme shown in this document.

The continuous voltage between the supply voltage and PE/gnd must not exceed 480V r.m.s.. Check for correct input polarity. The device will not operate when the voltage is reversed.

A disconnecting means shall be provided for the input of the device.

The device is designed for convection cooling and does not require an external fan. Do not obstruct airflow and do not cover ventilation grid!

The device is designed for altitudes up to 2000m (6560ft).

Keep the following minimum installation clearances: 40mm on top, 20mm on the bottom, 5mm left and right side. Increase the 5mm to 15mm in case the adjacent device is a heat source. When the device is permanently loaded with less than 50%, the 5mm can be reduced to zero.

For external branch protection consider diagram "Wiring Scheme". There are two options:

Option 1: For using the device powered by a B6 rectification the unit is tested and approved for branch circuits up to 25A. Do not use fuses smaller than 4A to avoid a nuisance tripping of the circuit breaker.

Option 2: For all other DC sources the device is tested and approved with max. 10A fuses in the plus and minus path. It is possible to use two devices on 10A fuses or one single device on 6A fuses. Do not use fuses smaller than 6A to avoid a nuisance tripping of the fuse. Use following fuse types with Option 2: Littelfuse type 0SPF010 or equivalent UL listed fuse, SIBA type URZ 5020434.

The maximum surrounding air temperature is +70°C (+158°F). The operational temperature is the same as the ambient or surrounding air temperature and is defined 2cm below the device.

The device is designed to operate in areas between 5% and 95% relative humidity.

## Functional Description

The output is electronically protected against no-load, overload and short circuit and can supply any kind of loads, including unlimited inductive loads and capacitive loads.

Do not apply return voltages from the load to the output terminals higher than 35V.

The output voltage can be adjusted with a small flat-blade screwdriver behind the flap on the front.

The green DC OK LED reports an output voltage above 90% of the adjusted voltage of a running device.

The DC OK relay monitors the output voltage and the contact is closed when the DC OK LED is on. Contact ratings: 60Vdc 0.3A, 30Vdc 1A, 30Vac 0.5A for resistive loads.

The red overload LED is on when the output voltage falls below 90% of the adjusted value or in case of a short circuit in the output. The LED is flashing, when the device has switched off due to over-temperature or when the "Remote OFF" signal is activated. Input voltage is required.

The device is equipped with an over-temperature protection. In case of a high temperature, the output shuts down and starts automatically again after cooling off.

Devices can be paralleled to increase the output power. The ambient temperature is not allowed to exceed +60°C. The output voltage of all devices shall be adjusted to the same value ( $\pm 100\text{mV}$ ) in "Single Use" mode with the same load conditions on all units, or the units can be left with the factory settings. After the adjustments, set the unit to "Parallel Use" mode, in order to achieve load sharing. The "Parallel Use" mode regulates the output voltage in such a manner that the voltage at no load is approx. 4% higher than at nominal load. If more than three devices are connected in parallel, a diode, fuse or circuit breaker with a rating of 50 or 63A is required on each output.

Same devices can be connected in series for higher output voltages. It is allowed to connect as many devices in series as needed, providing the sum of the output voltage does not exceed 150Vdc.

In case of an internal defect, a redundant circuit limits the maximum output voltage to 32V. The output shuts down and automatically attempts to restart.

The device is equipped with a remote ON/OFF function to turn the output off. For this connect pin 15 with pin 16.

The output voltage can be remotely adjusted between 14 and 28Vdc by applying a control voltage


between pin 15 and the (-) terminal. See product datasheet for details.

## Technical Data


All values are typical figures specified at 650Vdc input voltage, 24V, 40A output load, 25°C ambient temperature and after a 5 minutes run-in time unless otherwise noted.

| Output voltage             | DC 24V  | Nominal  |
|----------------------------|---|--|
| Adjustment range           | 24 – 28Vdc  | Factory setting 24,1V  |
| Output current             | Continuous:<br>40.0 – 34.3A<br>28.0 – 24.0 A<br>30.0 – 25.7A<br>21.0 – 18.0 | DC 475–750V, < +60°C<br>DC 320–474V, < +60°C<br>DC 475–750V, < +70°C<br>DC 320–474V, < +70°C<br>Derate linearly between +60°C and +70°C<br>Short-term, up to 4s:<br>60.0 – 51.5A<br>40.0 – 34.3A |
| Input voltage              | DC 475–750V   | -32.6%/+7%   |
| Input current              | 2.2–1.4A  |  |
| Input inrush current       | 5A peak   | Temp. independent  |
| Efficiency                 | 95.2%   |  |
| Losses                     | 48.4W   |  |
| Hold-up time               | typ. 25ms   |  |
| Temperature range          | -25 to +70°C  |  |
| Max. wire size (litz wire) | 4mm <sup>2</sup>  | For input terminals  |
| Wire size AWG              | AWG 20–10   | For input terminals  |
| Max. wire diameter         | 2.8mm   | For input terminals  |
| Wire stripping length      | 7mm / 0.28inch  | For input terminals  |
| Tightening torque          | 1Nm / 9lb.inch  | For input terminals  |
| Max. wire size (litz wire) | 10mm <sup>2</sup>   | For output terminals   |
| Wire size AWG              | AWG 22–8  | For output terminals   |
| Max. wire diameter         | 5.2mm   | For output terminals   |
| Wire stripping length      | 12mm / 0.5inch  | For output terminals   |
| Tightening torque          | 2.3Nm / 20lb.inch   | For output terminals   |
| Max. wire size (litz wire) | 1.5mm <sup>2</sup>  | For signal terminals   |
| Wire size AWG              | AWG 26–14   | For signal terminals   |
| Max. wire diameter         | 1.5mm   | For signal terminals   |
| Wire stripping length      | 7mm / 0.28inch  | For signal terminals   |
| Size (wxhx)                | 110x124x127mm   | Without DIN-rail   |
| Weight                     | 1500g / 3.3lb   |  |

## Functional Diagram



## Output Characteristic



## Wiring Scheme

