

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	BECKHOFF Automation GmbH & Co. KG		
Product name	TwinCAT BACnet		
Product model number	CX8191, CX9020, CX51x, CX52x, C60x -00x, C60x -0060, CP66x, CP67x -0001-00x, CP22x -00x, CP27x -00x		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.14
Firmware revision	4.0.1		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 19200, 38400, 57600, 76800, 115200	
	<input type="checkbox"/> PTP	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input checked="" type="checkbox"/> Router, medium: BACnet/IP – BACnet MS/TP	
Character set	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: AMEV BACnet 2017
<input type="checkbox"/> AMEV profile	As of:

3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS GmbH dated 08.01.2019 number VG 2018_17815
<input checked="" type="checkbox"/> AMEV recommendation BACnet 2017 As of: 01.08.2017 (see www.amev-online.de)

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30402 (see http://www.bacnetinternational.net/btl/)


Stuttgart, 29.04.2019



Dr.-Ing. Bernhard Hall
Vermögen und Bau Baden-Württemberg
Rotenbühlplatz 30
70195 Stuttgart
Telefon +49 711 6673-3433
Email Bernhard.Hall@vbv.bwl.de

(AMEV chairman BACnet)

WSP CERT



Dr.-Ing. Frank Bitter
Kapuzinerweg 7
70374 Stuttgart
Germany

(BACnet certification body)