EKRA D DEKRA DEKRA DEKRA DEKRA DEKRA DEKRA DEKRA DEKRA DEKRA EKRA DE

DEKRA

CERTIFICATE

(1) Type Examination

- (2) Equipment and protective systems intended for use in potentially explosive atmospheres Directive 94/9/EC
- (3) Type Examination Certificate Number: **KEMA 10ATEX0075 X** Issue Number: **5**
- (4) Equipment: Fieldbus Components Type BK ..., Type BC ..., Type KL ...,

Type KS ..., Type EK ..., Type EL ... and Type ES ...

- (5) Manufacturer: Beckhoff Automation GmbH & Co. KG
- (6) Address: Hülshorstweg 20, 33415 Verl, Germany
- (7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) DEKRA Certification B.V., certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report no. 213305100

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0: 2012 + A11: 2013 // EN 60079-15/2010

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This Type Examination Certificate relates only to the design, examination and tests of the specified equipment and not to the manufacturing process and supply of this equipment.
- (12) The marking of the equipment shall include the following:



/II 3/G////Ex/nA/IIC T4/Gc/or/Ex/nA/nC/IIC/T4/Gc

This certificate is issued on 3 July 2015 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.

R. Schuller

Certification Manager

Page 1/3

Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.



(13) SCHEDULE

(14) to Type Examination Certificate KEMA 10ATEX0075 X

Issue No. 5

(15) **Description**

Fieldbus Components Type BK ..., Type BC ..., Type KL ..., Type KS ..., Type EK ..., Type EL ... and Type ES ... for use in I/O and Fieldbus systems.

The description, the type code, the ambient temperature range and the temperature class of the components shall be taken from drawing ATEX1112FB05AS1, rev. 2.

Electrical data

The electrical data of the supply and the input and output circuits shall be taken from drawing ATEX1112FB05AS1, rev. 2.

Installation instructions

The manual provided with the equipment shall be followed in detail to assure safe operation.

(16) Test Report

No. 213305100.

(17) Special conditions for safe use

- The components Type BK ..., Type BC ..., Type KL ..., Type KS ..., Type EK ..., Type EL ...
 and Type ES, shall be installed in a suitable enclosure providing a degree of protection of at
 least IP54 according to EN 60079-15, taking into account the environmental conditions under
 which the equipment will be used.
- 2. When the temperature under rated conditions exceeds 70 °C at the cable or conduit entry point, or 80 °C at the branching point of the conductors, the temperature specification of the selected cable shall be in compliance with the actual measured temperature values.
- 3. Provisions shall be made to prevent the rated voltages from being exceeded by transient disturbances of more than 40%.
- 4. Components may only be removed or inserted when the system supply and the field supply are switched off, or when the location is known to be non-hazardous.
- 5. Fieldbus connectors may only be disconnected or connected when the system supply is switched off, or when the location is known to be non-hazardous.
- 6. The fuses, present in de the bus function terminals KL92xx may only be replaced when the supply is switched off, or when the location is known to be non-hazardous.
- 7. Address selectors and ID switches may only be adjusted when the system supply is switched off, or when the location is known to be non-hazardous.



(13) **SCHEDULE**

(14) to Type Examination Certificate KEMA 10ATEX0075 X

Issue No. 5

(18) Essential Health and Safety Requirements

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. 213305100.