



Product Service

CERTIFICATE

No. Z10 062386 0064 Rev. 03

Holder of Certificate: **Beckhoff Automation GmbH & Co. KG**
Hülshorstweg 20
33415 Verl
GERMANY

Certification Mark:



Product: **Safety components**
Model(s): **AX 8 Series**

Parameters: Safety integrity level: up to SIL 3
Category: Cat. 4
Performance level: PLe

The report listed below is a mandatory part of certificate.

Tested according to: IEC 61508-1:2010 (up to SIL3)
IEC 61508-2:2010 (up to SIL3)
IEC 61508-3:2010 (up to SIL3)
IEC 62061:2021 (SIL 3)
EN ISO 13849-1:2023
IEC 61800-5-2:2016
EN 61511-1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: **BV99611C**
Valid until: 2029-04-03

Date, 2025-04-04

(Günter Greil)