



Product Service

CERTIFICATE

No. Z10 062386 0126 Rev. 00

Holder of Certificate: **Beckhoff Automation GmbH & Co. KG**

Hülshorstweg 20
33415 Verl
GERMANY

Certification Mark:



Product: **Safety components**

Model(s): **MO2914**

Parameters:

Safety integrity level:	up to SIL 3
Category:	Cat. 4
Performance level:	PLe

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report BV105442C in the current valid revision.

Tested according to:

- IEC 61508-1:2010 (up to SIL3)
- IEC 61508-2:2010 (up to SIL3)
- IEC 61508-3:2010 (up to SIL3)
- IEC 62061:2021 (maximum SIL 3)
- EN ISO 13849-1:2023 (up to Cat. 4 PL e)
- EN 61511-1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: BV105442C
Valid until: 2030-08-12

Date, 2025-08-14

(Peter Weiß)