

Documentation | EN

EP3752-0000

2 x 3-axis accelerometers



Table of contents

1 Foreword	5
1.1 Notes on the documentation	5
1.2 Safety instructions	6
1.3 Documentation issue status	7
2 EtherCAT Box - Introduction	8
3 Product overview	10
3.1 Introduction	10
3.2 Technical data	11
3.3 Process image	13
4 Mounting and cabling	14
4.1 Mounting	14
4.1.1 Dimensions	14
4.1.2 Fixing	15
4.1.3 Nut torque for connectors	15
4.2 Supply voltages	16
4.2.1 Connectors	17
4.2.2 Status LEDs	17
4.2.3 Conductor losses	18
4.3 EtherCAT	19
4.3.1 Connectors	19
4.3.2 Status LEDs	20
4.3.3 Cables	20
4.4 UL Requirements	21
4.5 Disposal	22
5 Commissioning/Configuration	23
5.1 Integrating into a TwinCAT project	23
5.2 Acceleration sensors	24
5.2.1 Settings	25
5.2.2 Inclination measurement	29
5.3 Restore the delivery state	32
5.4 Decommissioning	34
6 CoE parameters	35
6.1 Object overview	35
6.2 Object description and parameterization	39
7 Appendix	50
7.1 General operating conditions	50
7.2 Accessories	51
7.3 Version identification of EtherCAT devices	52
7.3.1 General notes on marking	52
7.3.2 Version identification of IP67 modules	53
7.3.3 Beckhoff Identification Code (BIC)	54
7.3.4 Electronic access to the BIC (eBIC)	56
7.4 Support and Service	58

1 Foreword

1.1 Notes on the documentation

Intended audience

This description is only intended for the use of trained specialists in control and automation engineering who are familiar with the applicable national standards.

It is essential that the documentation and the following notes and explanations are followed when installing and commissioning these components.

The qualified personnel is obliged to always use the currently valid documentation.

The responsible staff must ensure that the application or use of the products described satisfy all the requirements for safety, including all the relevant laws, regulations, guidelines and standards.

Disclaimer

The documentation has been prepared with care. The products described are, however, constantly under development.

We reserve the right to revise and change the documentation at any time and without prior announcement.

No claims for the modification of products that have already been supplied may be made on the basis of the data, diagrams and descriptions in this documentation.

Trademarks

Beckhoff®, ATRO®, EtherCAT®, EtherCAT G®, EtherCAT G10®, EtherCAT P®, MX-System®, Safety over EtherCAT®, TC/BSD®, TwinCAT®, TwinCAT/BSD®, TwinSAFE®, XFC®, XPlanar® and XTS® are registered trademarks of and licensed by Beckhoff Automation GmbH.

Other designations used in this publication may be trademarks whose use by third parties for their own purposes could violate the rights of the owners.



EtherCAT® and EtherCAT P® are registered trademarks and patented technologies, licensed by Beckhoff Automation GmbH, Germany.

Copyright

© Beckhoff Automation GmbH & Co. KG, Germany.

The reproduction, distribution and utilization of this document as well as the communication of its contents to others without express authorization are prohibited.

Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent, utility model or design.

Third-party brands

Trademarks of third parties may be used in this documentation. You can find the trademark notices here: <https://www.beckhoff.com/trademarks>

1.2 Safety instructions

Safety regulations

Please note the following safety instructions and explanations!

Product-specific safety instructions can be found on following pages or in the areas mounting, wiring, commissioning etc.

Exclusion of liability

All the components are supplied in particular hardware and software configurations appropriate for the application. Modifications to hardware or software configurations other than those described in the documentation are not permitted, and nullify the liability of Beckhoff Automation GmbH & Co. KG.

Personnel qualification

This description is only intended for trained specialists in control, automation and drive engineering who are familiar with the applicable national standards.

Signal words

The signal words used in the documentation are classified below. In order to prevent injury and damage to persons and property, read and follow the safety and warning notices.

Personal injury warnings

DANGER

Hazard with high risk of death or serious injury.

WARNING

Hazard with medium risk of death or serious injury.

CAUTION

There is a low-risk hazard that could result in medium or minor injury.

Warning of damage to property or environment

NOTICE

The environment, equipment, or data may be damaged.

Information on handling the product



This information includes, for example:
recommendations for action, assistance or further information on the product.

1.3 Documentation issue status

Version	Comment
1.5	"Inclination measurement" chapter updated
1.4	- Chapter "Scaling of measured values" updated - Structure update
1.3	- Dimensions updated - UL requirements updated
1.2	- Technical data updated - Structure update
1.1	- Corrections "Resolution" section added ("Technical data" chapter)
1.0	First release
0.3	Corrections
0.2	Corrections
0.1	First preliminary version

Firmware and hardware versions

This documentation refers to the firmware and hardware version that was applicable at the time the documentation was written.

The module features are continuously improved and developed further. Modules having earlier production statuses cannot have the same properties as modules with the latest status. However, existing properties are retained and are not changed, so that older modules can always be replaced with new ones.

Documentation	Firmware	Hardware
1.5	02	11
1.4	02	07
1.3	02	06
1.2	02	05
1.1	02	03
1.0	01	02

The firmware and hardware version (delivery state) can be found in the batch number (D-number) printed on the side of the EtherCAT Box.

Syntax of the batch number (D-number)

D: WW YY FF HH

WW - week of production (calendar week)

YY - year of production

FF - firmware version

HH - hardware version

Example with D no. 29 10 02 01:

29 - week of production 29

10 - year of production 2010

02 - firmware version 02

01 - hardware version 01

Further information on this topic: [Version identification of EtherCAT devices](#) [► 52].

2 EtherCAT Box - Introduction

The EtherCAT system has been extended with EtherCAT Box modules with protection rating IP67. Through the integrated EtherCAT interface the modules can be connected directly to an EtherCAT network without an additional Coupler Box. The high-performance of EtherCAT is thus maintained into each module.

The extremely low dimensions of only 126 x 30 x 26.5 mm (h x w x d) are identical to those of the Fieldbus Box extension modules. They are thus particularly suitable for use where space is at a premium. The small mass of the EtherCAT modules facilitates applications with mobile I/O interface (e.g. on a robot arm). The EtherCAT connection is established via screened M8 connectors.




Fig. 1: EtherCAT Box Modules within an EtherCAT network

The robust design of the EtherCAT Box modules enables them to be used directly at the machine. Control cabinets and terminal boxes are now no longer required. The modules are fully sealed and therefore ideally prepared for wet, dirty or dusty conditions.

Pre-assembled cables significantly simplify EtherCAT and signal wiring. Very few wiring errors are made, so that commissioning is optimized. In addition to pre-assembled EtherCAT, power and sensor cables, field-configurable connectors and cables are available for maximum flexibility. Depending on the application, the sensors and actuators are connected through M8 or M12 connectors.

The EtherCAT modules cover the typical range of requirements for I/O signals with protection rating IP67:

- digital inputs with different filters (3.0 ms or 10 μ s)
- digital outputs with 0.5 or 2 A output current
- analog inputs and outputs with 16 bit resolution
- Thermocouple and RTD inputs
- Stepper motor modules

XFC (eXtreme Fast Control Technology) modules, including inputs with time stamp, are also available.



Fig. 2: EtherCAT Box with M8 connections for sensors/actuators




Fig. 3: EtherCAT Box with M12 connections for sensors/actuators

Basic EtherCAT documentation

i You will find a detailed description of the EtherCAT system in the Basic System Documentation for EtherCAT, which is available for download from our website (www.beckhoff.com) under Downloads.

3 Product overview

3.1 Introduction



2 x 3-axis accelerometers

The EP3752-0000 EtherCAT Box has two internal 3-axis accelerometers with 10-bit resolution and a selectable measuring range of ± 2 g, ± 4 g, ± 8 g and ± 16 g. The maximum sampling rate is 5 kHz. The measured values can be digitally filtered. Without filters the box operates cycle-synchronously.

Possible applications include the recording of vibrations and shocks/oscillations, but inclination measurements in all three axes are also possible.

Through the measurement using sensors offset by 90° , the controller can carry out a plausibility check of the data. Extended integrated filter functions enable the pre-processing and scaling of the acquired data in order to filter out faults and relieve the controller.

3.2 Technical data

All values are typical values over the entire temperature range, unless stated otherwise.

EtherCAT	
Connection	2 x M8 socket, 4-pin, A-coded, shielded
Electrical isolation	500 V
Minimum cycle time	200 µs

Supply voltages	
Connection	Input: M8 connector, 4-pin, A-coded Downstream connection: M8 socket, 4-pin, A-coded
U _S rated voltage	24 V DC (-15%, +20%)
U _S sum current: I _{S,sum}	max. 4 A
Current consumption from U _S	120 mA
Rated voltage U _P	24 V DC (-15 %, +20 %)
U _P sum current: I _{P,sum}	max. 4 A
Current consumption from U _P	None. U _P is only forwarded.

Accelerometers	
Sensor type	Two 3-axis sensors / offset by 90°
Resolution ^{1) 2)}	Measured values: 4 mg (default) Raw values: 10-bit (default)
Representation ¹⁾	Measured values: 1 mg / LSB Raw values: 10-bit in 16-bit (left aligned)
Measuring range ¹⁾	±2 g / ±4 g / ±8 g / ±16 g selectively
Sampling rate	200 Hz to 5 kHz

¹⁾ Unit of measurement: 1 g = 9.81 m/s² (acceleration of gravity). 1 mg = 1/1000 g.

²⁾ The resolution depends on the parameterization of the box. See section [Resolution](#) [► 12].

Housing data	
Dimensions W × H × D	30 mm × 126 mm × 26.5 mm (without connectors)
Weight	approx. 165 g
Installation position	variable
Material	PA6 (polyamide)

Environmental conditions	
Ambient temperature during operation	-25...+60 °C -25...+55 °C according to cURus
Ambient temperature during storage	-40...+85 °C
Vibration resistance, shock resistance	conforms to EN 60068-2-6 / EN 60068-2-27 Additional tests [► 12]
EMC immunity / emission	conforms to EN 61000-6-2 / EN 61000-6-4
Protection rating	IP65, IP66, IP67 (conforms to EN 60529)

Approvals/markings	
Approvals/markings ^{*)}	CE, cURus [► 21]

^{*)} Real applicable approvals/markings see type plate on the side (product marking).

Resolution

The resolution of measured values and raw values depends on the parameters "Measuring range" and "Sampling rate". The table below shows how these parameters influence the resolution:

Measuring range	Sampling rate / EtherCAT cycle time	Resolution	
		Raw values	Measured values
±2 g	≤ 1 kHz / ≥ 1 ms	10-bit	4 mg
±4 g			8 mg
±8 g			16 mg
±16 g			48 mg
±2 g	> 1 kHz / < 1 ms	8-bit	16 mg
±4 g			32 mg
±8 g			64 mg
±16 g			192 mg


The setting of the "Measuring range" and "Sampling rate" parameters is described in the chapter [Settings](#) [► 25].

Additional tests

The devices have undergone the following additional tests:

Test	Explanation
Vibration	10 frequency sweeps in 3 axes
	5 Hz < f < 60 Hz displacement 0.35 mm, constant amplitude
	60.1 Hz < f < 500 Hz acceleration 5 g, constant amplitude
Shocks	1000 shocks in each direction, in 3 axes
	35 g, 11 ms

3.3 Process image



The data for the two accelerometers can be found under **AI Inputs Channel**.


- Status Error: An error occurred during communication with the accelerometer.
- Value: 16-bit acceleration value

The assignment of the process values to the sensor axes can be found in the chapter [Acceleration sensors](#) [► 24].

4 Mounting and cabling

4.1 Mounting

4.1.1 Dimensions



All dimensions are given in millimeters.
The drawing is not true to scale.

Housing features

Housing material	PA6 (polyamide)
Sealing compound	polyurethane
Mounting	two mounting holes Ø 3.5 mm for M3
Metal parts	brass, nickel-plated
Contacts	CuZn, gold-plated
Installation position	variable
Protection rating	IP65, IP66, IP67 (conforms to EN 60529) when screwed together
Dimensions (H × W × D)	approx. 126 × 30 × 26.5 mm (without connectors)

4.1.2 Fixing

NOTICE

Dirt during assembly

Dirty connectors can lead to malfunctions. Protection rating IP67 can only be guaranteed if all cables and connectors are connected.

- Protect the plug connectors against dirt during the assembly.

Mount the module with two M3 screws on the mounting holes in the corners of the module. The mounting holes have no thread.

4.1.3 Nut torque for connectors

Screw M8 connectors tight with a torque wrench. (e.g. ZB8801 from Beckhoff)

Torque: 0.4 Nm.

4.2 Supply voltages

⚠ WARNING

Power supply from SELV / PELV power supply unit!

SELV / PELV circuits (safety extra-low voltage / protective extra-low voltage) according to IEC 61010-2-201 must be used to supply this device.

Notes:

- SELV / PELV circuits may give rise to further requirements from standards such as IEC 60204-1 et al, for example with regard to cable spacing and insulation.
- A SELV supply provides safe electrical isolation and limitation of the voltage without a connection to the protective conductor, a PELV supply also requires a safe connection to the protective conductor.

⚠ CAUTION

Observe the UL requirements

- When operating under UL conditions, observe the warnings in the chapter [UL Requirements](#) [► 21].

The EtherCAT Box has one input for two supply voltages:

- **Control voltage U_s**
The following sub-functions are supplied from the control voltage U_s :
 - the fieldbus
 - the processor logic
 - typically the inputs and the sensors if the EtherCAT Box has inputs.
- **Peripheral voltage U_p**
For EtherCAT Box modules with digital outputs the digital outputs are typically supplied from the peripheral voltage U_p . U_p can be supplied separately. If U_p is switched off, the fieldbus function, the function of the inputs and the supply of the sensors are maintained.

The exact assignment of U_s and U_p can be found in the pin assignment of the I/O connections.

Redirection of the supply voltages

The power IN and OUT connections are bridged in the module. Hence, the supply voltages U_s and U_p can be passed from EtherCAT Box to EtherCAT Box in a simple manner.

NOTICE

Note the maximum current!

Ensure that the permitted current for the connectors is not exceeded when routing the supply voltages U_s and U_p :

M8 connector: max. 4 A
7/8" connector: max 16 A

NOTICE

Unintentional cancellation of the electrical isolation possible

In some types of EtherCAT Box modules the ground potentials GND_s and GND_p are connected.

- If several EtherCAT Box modules are supplied with the same electrically isolated voltages, check whether there is an EtherCAT Box among them in which the ground potentials are connected.


4.2.1 Connectors

NOTICE


Risk of confusion: supply voltages and EtherCAT

Defect possible through incorrect insertion.

- Observe the color coding of the connectors:
black: Supply voltages
green: EtherCAT



Plug
Input



Socket
Forwarding

Contact	Function	Description	Core color ¹⁾
1	U _S	Control voltage	Brown
2	U _P	Peripheral voltage	White
3	GND _S	GND to U _S	Blue
4	GND _P	GND to U _P	Black

¹⁾ The core colors apply to cables of the type: Beckhoff ZK2020-3xxx-xxxx

4.2.2 Status LEDs





LED	Display	Meaning
U _S (control voltage)	off	The supply voltage U _S is not available.
	green illuminated	The supply voltage U _S is available.
U _P (peripheral voltage)	off	The supply voltage U _P is not available.
	green illuminated	The supply voltage U _P is available.

4.2.3 Conductor losses

Take into account the voltage drop on the supply line when planning a system. Avoid the voltage drop being so high that the supply voltage at the box lies below the minimum nominal voltage. Variations in the voltage of the power supply unit must also be taken into account.

Voltage drop on the supply line



4.3 EtherCAT

4.3.1 Connectors

NOTICE

Risk of confusion: supply voltages and EtherCAT
Defect possible through incorrect insertion.

- Observe the color coding of the connectors:
black: Supply voltages
green: EtherCAT

EtherCAT Box Modules have two green M8 sockets for the incoming and downstream EtherCAT connections.



Connection




Fig. 4: M8 socket

EtherCAT	M8 socket	Core colors		
Signal	Contact	ZB9010, ZB9020, ZB9030, ZB9032, ZK1090-6292, ZK1090-3xxx-xxxx	ZB9031 and old versions of ZB9030, ZB9032, ZK1090-3xxx-xxxx	TIA-568B
Tx +	1	yellow ¹⁾	orange/white	white/orange
Tx -	4	orange ¹⁾	orange	orange
Rx +	2	white ¹⁾	blue/white	white/green
Rx -	3	blue ¹⁾	blue	green
Shield	Housing	Shield	Shield	Shield

¹⁾ Core colors according to EN 61918

i Adaptation of core colors for cables ZB9030, ZB9032 and ZK1090-3xxxx-xxxx

For standardization, the core colors of the ZB9030, ZB9032 and ZK1090-3xxx-xxxx cables have been changed to the EN61918 core colors: yellow, orange, white, blue. So there are different color codes in circulation. The electrical properties of the cables have been retained when the core colors were changed.

4.3.2 Status LEDs



L/A (Link/Act)

A green LED labelled "L/A" is located next to each EtherCAT socket. The LED indicates the communication state of the respective socket:

LED	Meaning
off	no connection to the connected EtherCAT device
lit	LINK: connection to the connected EtherCAT device
flashes	ACT: communication with the connected EtherCAT device

Run

Each EtherCAT slave has a green LED labelled "Run". The LED signals the status of the slave in the EtherCAT network:

LED	Meaning
off	Slave is in "Init" state
flashes uniformly	Slave is in "Pre-Operational" state
flashes sporadically	Slave is in "Safe-Operational" state
lit	Slave is in "Operational" state

Description of the EtherCAT slave states

4.3.3 Cables

For connecting EtherCAT devices only shielded Ethernet cables that meet the requirements of at least category 5 (CAT5) according to EN 50173 or ISO/IEC 11801 should be used.

EtherCAT uses four wires for signal transmission.

Thanks to automatic line detection ("Auto MDI-X"), both symmetrical (1:1) or cross-over cables can be used between Beckhoff EtherCAT.

Detailed recommendations for the cabling of EtherCAT devices

4.4 UL Requirements

The installation of the EtherCAT Box Modules certified by UL has to meet the following requirements.

Supply voltage

⚠ CAUTION

These UL requirements are valid for all supply voltages of all marked EtherCAT Box Modules.

For the compliance of the UL requirements the EtherCAT Box Modules should only be supplied

- by a 24 V DC supply voltage, supplied by an isolating source and protected by means of a fuse (in accordance with UL248), rated maximum 4 Amp, or
- by a 24 V DC power source, that has to satisfy *NEC class 2*.
A *NEC class 2* power supply shall not be connected in series or parallel with another (class 2) power source

⚠ CAUTION

To meet the UL requirements, the EtherCAT Box Modules must not be connected to unlimited power sources

Networks

⚠ CAUTION

To meet the UL requirements, EtherCAT Box Modules must not be connected to telecommunication networks.

Ambient temperature range

⚠ CAUTION

To meet the UL requirements, EtherCAT Box Modules have to be operated only at an ambient temperature range of -25 °C to +55 °C.

Marking for UL

All EtherCAT Box Modules certified by UL (Underwriters Laboratories) are marked with the following label.



Fig. 5: UL label

4.5 Disposal



Products marked with a crossed-out wheeled bin shall not be discarded with the normal waste stream. The device is considered as waste electrical and electronic equipment. The national regulations for the disposal of waste electrical and electronic equipment must be observed.

5 Commissioning/Configuration

5.1 Integrating into a TwinCAT project

The procedure for integration in a TwinCAT project is described in these [Quick start guide](#).


5.2 Acceleration sensors

The EP3752-0000 has two accelerometers. Each accelerometer measures the acceleration in all three spatial directions.

The accelerometers are offset by 90°. This enables a plausibility check of the measured values.

The measured acceleration values can be converted to inclination angles: see chapter on [Inclination measurement](#) [► 29].


Assignment of the acceleration axes to the process variables [► 13]



5.2.1 Settings

5.2.1.1 Measuring range

You can select the measuring range in the CoE parameter 0xF800:11 "Range".




If you select the option "Channel setting", you can set the measuring range for each sensor individually:

- Measuring range for sensor 1: Index 0x8000:19 "Range"
- Measuring range for sensor 2: Index 0x8030:19 "Range"

This setting applies to all axes of the respective sensor. An individual setting for individual axes is not possible.

5.2.1.2 Scaling of the measured values

In the factory setting, the measured values are scaled to 1 mg / LSB. You can set the scaling of the measured values in CoE parameter F800:1D "Presentation".




The following options are available:

Option	Description
"Raw Values"	The measured values of all acceleration axes are output without scaling as unprocessed raw values of the accelerometers. The resolution of the raw values is not higher than the resolution of the measured values in mg. See diagram below.
"milli G (mG)" (default)	The measured values of all acceleration axes are scaled to 1 mg / LSB.
"Channel setting"	This option allows you to set the scaling of the measured values for each axis individually. Set the desired scaling in the CoE parameters 0x80n0:1A.

Transfer function

The following diagram shows the transfer function of the box.



It can be seen that the resolution of the raw values is as high as the resolution of the measured values in mg.

5.2.1.3 Filter

Filter mode (FIR and IIR)

The EP3752-0000 is equipped with digital filters which, depending on their settings, can adopt the characteristics of a *Finite Impulse Response* filter (*FIR filter*), or of an *Infinite Impulse Response* filter (*IIR-Filter*). The filters are deactivated by default. The activation takes place

- individually for each channel via the indices 0x80n0:06 [► 40] from Firmware 02.
- centrally via the 1st channel (index 0x8000:06 [► 40]) with Firmware 01.

The filter characteristic is selected individually for each channel via the indices 0x80n0:15 "Filter Settings":

FIR

The mean value of the last 32 measurements is calculated. The internal sampling rate (time interval between the individual measured values) can be parameterized via index 0xF800:0D "Filter sampling rate".

IIR1...8

The filter with IIR characteristic can be set to one of 8 levels. The higher the level, the higher the attenuation of the present signal by the filter. The internal sampling rate can be set via index 0xF800:0D "Filter sampling rate" (unlike other analog boxes in which a fixed cycle time of 1 ms is specified).

Setting of the internal sampling rate via index 0xF800:0D




Fig. 6: Setting of the internal sampling rate (index 0xF800:0D)

The internal sampling rate with filters switched on is set via the index 0xF800:0D. On delivery this is set to 1000 Hz.



Changing the update rate at 2000 Hz and 5000 Hz

The resolution is reduced to 8-bit if the rate is increased to 2500 Hz or 5000 Hz. This is necessary due to the sensors used.

5.2.1.4 Sampling rate and synchronization

The sampling rate depends on whether the box's filters are activated. The filters are disabled by default. They are described in the chapter [Filter](#) [► 27].

- If all filters are disabled,
the box works SM-synchron. In this mode the EtherCAT cycle time determines the sampling rate: in each EtherCAT cycle the measured values are read out from the sensors.
The sensor operates internally with 10 bits up to a cycle time of 1 ms. Below this, the resolution drops to 8 bits. The minimum cycle time is 200 µs.
- If at least one filter is enabled,
the box runs in FreeRun mode with a sampling rate adjustable via CoE index 0xF800:0D "Filter sampling rate".
If the sampling rate is increased to 2500 Hz or 5000 Hz, the resolution is reduced to 8-bit.

5.2.2 Inclination measurement

The calculation of an angle with higher resolution and accuracy should take place on a PC. The sensors used are capable of an accuracy of less than 0.1° .

Since the angle values are derived from the acceleration values, which are subject to certain noise, they have to be filtered via suitable algorithms.

In simple cases this could be a sliding average value, for example.



Fig. 7: Angle measurement, process data as acceleration values, calculation on a PC




Fig. 8: Signal noise in detail

Color	Meaning
Red	Angle measured with 1024-step encoder / 4-way analysis for reference
Green	Angle trigonometrically calculated on a PC, without noise suppression
blue	Fast algorithm
yellow	Arithmetic mean (1000 sliding values)

Sample program 1: Calculating roll and pitch

This sample program demonstrates how to calculate the roll and pitch angles based on the measured acceleration values.

```
PROGRAM MAIN

VAR
    (* Acceleration values *)
    fX_11 AT %I* : INT;
    fY_11 AT %I* : INT;
    fZ_11 AT %I* : INT;
    pi: LREAL;

    fRoll : LREAL; (* Angle about X-axis *)
    fPitch : LREAL; (* Angle about Y-axis *)
END_VAR

pi:=3.14159265;

IF fX_11 <> 0 AND fZ_11 <> 0 THEN
    fRoll := ATAN(fY_11/SQRT(EXPT(fX_11,2)+EXPT(fZ_11,2)));
    IF fRoll < 0 THEN
        fRoll := fRoll + 2*pi;
    END_IF
    fRoll := fRoll*180/pi;
END_IF

IF fY_11 <> 0 AND fZ_11 <> 0 THEN
    fPitch := ATAN(fX_11/SQRT(EXPT(fY_11,2)+EXPT(fZ_11,2)));
    IF fPitch < 0 THEN
        fPitch := fPitch + 2*pi;
    END_IF
    fPitch := fPitch*180/pi;
END_IF
```

Sample program 2: Calculating the angle between two measurement states

This sample program demonstrates how to calculate the angle between the current acceleration vector and a reference acceleration vector.

```
PROGRAM MAIN

VAR
    (* Acceleration values *)
    fX_11 AT %I* : INT;
    fY_11 AT %I* : INT;
    fZ_11 AT %I* : INT;

    fAbsLast: LREAL;
    bStoreInitial: BOOL;
    fAbsInit: LREAL;
    pi: LREAL;
    fXInit: LREAL;
    fYInit: LREAL;
    fZInit: LREAL;

    fAlpha: LREAL;
END_VAR


pi:=3.14159265;

IF bStoreInitial THEN
    fXInit := fX_11;
    fYInit := fY_11;
    fZInit := fZ_11;
    bStoreInitial := FALSE;
END_IF

fAbsInit := SQRT(EXPT(fXInit,2)+EXPT(fYInit,2)+EXPT(fZInit,2));
fAbsLast := SQRT(EXPT(fX_11,2)+EXPT(fY_11,2)+EXPT(fZ_11,2));

IF fAbsInit <> 0 AND fAbsLast <> 0 THEN
    fAlpha := ACOS((fXInit*fX_11 + fYInit*fY_11 + fZInit*fZ_11)/(fAbsInit*fAbsLast))*180/pi;
END_IF
```

Sample



Equation for calculating the angle α :

$$\alpha = \tan^{-1}\left(\frac{a_{y1}}{\sqrt{a_{x1}^2 + a_{z1}^2}}\right) * \frac{360^\circ}{2\pi}$$

Implementation in TwinCAT:

```
alpha := ATAN(a_y1 / (SQRT(a_x1 * a_x1 + a_z1 * a_z1))) * 360 / (2*3.14);
```

5.3 Restore the delivery state


EtherCAT devices have two options for restoring the delivery status:

- **Function reset ("load"):** Resets changeable CoE parameters to their default values. This procedure is typically used during commissioning.
- **Data reset ("wipe"):** Deletes all user-specific data completely. This procedure is intended for a complete reset, e.g. when decommissioning.


Function reset ("load")

You can restore the delivery status of all changeable CoE parameters with the function reset ("load") as follows:

1. Ensure that TwinCAT is in the CONFIG or RUN state and that EtherCAT communication is running error-free.
2. In CoE object 1011:0, "Restore default parameters" select parameter 1011:01."Subindex 001"



3. Double click on "Subindex 001".
⇒ The dialog box "Set Value Dialog" opens.
4. Enter the value 1684107116 in the field "Dec".
Alternatively, enter the value 0x64616F6C in the field "Hex".



For some EtherCAT devices with firmware version before approx. 2007, the value 1819238756 is required instead.

Alternatively, enter the value 0x6C6F6164 in the field "Hex".

5. Confirm with "OK".

⇒ All changeable CoE parameters are reset to the default values.

Exception: CoE parameters that are protected by a write protection password.

Properties of the function reset ("load"):

- Depending on the EtherCAT devices, execution takes a few milliseconds to over 1 second.
- The execution is not confirmed.
- Entering an incorrect value has no effect.
- Depending on the device, individual CoE parameter values are not reset.
- Existing checksums for the parameter ranges will change.

Data reset ("wipe")

Proceed as for the function reset ("load"), but enter the value 2003398757 in the "Dec" field; alternatively, enter the value 0x77697065 in the "Hex" field.

Result:

- All user-specific data is deleted completely:
 - CoE
 - SoE
 - FoE
 - Register values
 - User memory
- Password protected data is also reset
- The following data will not be reset:
 - firmware
 - EtherCAT revision
 - persistent diagnostic data such as the object 0x1020 "Device Statistics", operating hours counter, peak values
 - manufacturer adjustment data

5.4 Decommissioning

WARNING

Risk of electric shock!

Bring the bus system into a safe, de-energized state before starting disassembly of the devices!

6 CoE parameters

6.1 Object overview



EtherCAT XML Device Description

The display matches that of the CoE objects from the EtherCAT XML Device Description. We recommend downloading the latest XML file from the download area of the Beckhoff website and installing it according to installation instructions.

Index (hex)		Name	Flags	Default value
1000 [► 44]		Device type	RO	0x00001389 (5001 _{dec})
1008 [► 44]		Device name	RO	EP3752-0000
1009 [► 44]		Hardware version	RO	00
100A [► 44]		Software version	RO	00
1011:0 [► 39]	Subindex	Restore default parameters	RO	0x01 (1 _{dec})
	1011:01	SubIndex 001	RW	0x00000000 (0 _{dec})
1018:0 [► 44]	Subindex	Identity	RO	0x04 (4 _{dec})
	1018:01	Vendor ID	RO	0x00000002 (2 _{dec})
	1018:02	Product code	RO	0x0EA84052 (245907538 _{dec})
	1018:03	Revision	RO	0x00100002 (1048578 _{dec})
	1018:04	Serial number	RO	0x00000000 (0 _{dec})
10F0:0 [► 44]	Subindex	Backup parameter handling	RO	0x01 (1 _{dec})
	10F0:01	Checksum	RO	0x00000000 (0 _{dec})
1A00:0 [► 45]	Subindex	AI TxPDO-Map Inputs Ch.1	RO	0x06 (6 _{dec})
	1A00:01	SubIndex 001	RO	0x0000:00, 6
	1A00:02	SubIndex 002	RO	0x6000:07, 1
	1A00:03	SubIndex 003	RO	0x0000:00, 7
	1A00:04	SubIndex 004	RO	0x6000:0F, 1
	1A00:05	SubIndex 005	RO	0x6000:10, 1
	1A00:06	SubIndex 006	RO	0x6000:11, 16
1A01:0 [► 45]	Subindex	AI TxPDO-Map Inputs Ch.2	RO	0x06 (6 _{dec})
	1A01:01	SubIndex 001	RO	0x0000:00, 6
	1A01:02	SubIndex 002	RO	0x6010:07, 1
	1A01:03	SubIndex 003	RO	0x0000:00, 7
	1A01:04	SubIndex 004	RO	0x6010:0F, 1
	1A01:05	SubIndex 005	RO	0x6010:10, 1
	1A01:06	SubIndex 006	RO	0x6010:11, 16
1A02:0 [► 45]	Subindex	AI TxPDO-Map Inputs Ch.3	RO	0x06 (6 _{dec})
	1A02:01	SubIndex 001	RO	0x0000:00, 6
	1A02:02	SubIndex 002	RO	0x6020:07, 1
	1A02:03	SubIndex 003	RO	0x0000:00, 7
	1A02:04	SubIndex 004	RO	0x6020:0F, 1
	1A02:05	SubIndex 005	RO	0x6020:10, 1
	1A02:06	SubIndex 006	RO	0x6020:11, 16
1A03:0 [► 45]	Subindex	AI TxPDO-Map Inputs Ch.4	RO	0x06 (6 _{dec})
	1A03:01	SubIndex 001	RO	0x0000:00, 6
	1A03:02	SubIndex 002	RO	0x6030:07, 1
	1A03:03	SubIndex 003	RO	0x0000:00, 7
	1A03:04	SubIndex 004	RO	0x6030:0F, 1
	1A03:05	SubIndex 005	RO	0x6030:10, 1
	1A03:06	SubIndex 006	RO	0x6030:11, 16
1A04:0 [► 46]	Subindex	AI TxPDO-Map Inputs Ch.5	RO	0x06 (6 _{dec})
	1A04:01	SubIndex 001	RO	0x0000:00, 6
	1A04:02	SubIndex 002	RO	0x6040:07, 1
	1A04:03	SubIndex 003	RO	0x0000:00, 7
	1A04:04	SubIndex 004	RO	0x6040:0F, 1
	1A04:05	SubIndex 005	RO	0x6040:10, 1
	1A04:06	SubIndex 006	RO	0x6040:11, 16

Index (hex)		Name	Flags	Default value
1A05:0 ▶ 46	Subindex	AI TxPDO-Map Inputs Ch.6	RO	0x06 (6 _{dec})
	1A05:01	SubIndex 001	RO	0x0000:00, 6
	1A05:02	SubIndex 002	RO	0x6050:07, 1
	1A05:03	SubIndex 003	RO	0x0000:00, 7
	1A05:04	SubIndex 004	RO	0x6050:0F, 1
	1A05:05	SubIndex 005	RO	0x6040:10, 1
	1A05:06	SubIndex 006	RO	0x6050:11, 16
	1A05:02	AI TxPDO-Map Inputs Ch.5	RO	0x06 (6 _{dec})
1C00:0 ▶ 46	Subindex	Sync manager type	RO	0x04 (4 _{dec})
	1C00:01	SubIndex 001	RO	0x01 (1 _{dec})
	1C00:02	SubIndex 002	RO	0x02 (2 _{dec})
	1C00:03	SubIndex 003	RO	0x03 (3 _{dec})
	1C00:04	SubIndex 004	RO	0x04 (4 _{dec})
1C12:0 ▶ 46	Subindex	RxPDO assign	RW	0x00 (0 _{dec})
1C13:0 ▶ 46	Subindex	TxPDO assign	RW	0x06 (6 _{dec})
	1C13:01	SubIndex 001	RW	0x1A00 (6656 _{dec})
	1C13:02	SubIndex 002	RW	0x1A02 (6658 _{dec})
	1C13:03	SubIndex 003	RW	0x1A03 (6659 _{dec})
	1C13:04	SubIndex 004	RW	0x1A04 (6660 _{dec})
	1C13:05	SubIndex 005	RW	0x1A05 (6661 _{dec})
	1C13:06	SubIndex 006	RW	0x1A06 (6662 _{dec})
1C33:0 ▶ 47	Subindex	SM input parameter	RO	0x20 (32 _{dec})
	1C33:01	Sync mode	RW	0x0022 (34 _{dec})
	1C33:02	Cycle time	RW	0x000F4240 (1000000 _{dec})
	1C33:03	Shift time	RO	0x00000000 (0 _{dec})
	1C33:04	Sync modes supported	RO	0x0003 (3 _{dec})
	1C33:05	Minimum cycle time	RO	0x00030D40 (200000 _{dec})
	1C33:06	Calc and copy time	RO	0x00000000 (0 _{dec})
	1C33:07	Minimum delay time	RO	0x00000000 (0 _{dec})
	1C33:08	Command	RW	0x0000 (0 _{dec})
	1C33:09	Maximum Delay time	RO	0x00000000 (0 _{dec})
	1C33:0B	SM event missed counter	RO	0x0000 (0 _{dec})
	1C33:0C	Cycle exceeded counter	RO	0x0000 (0 _{dec})
	1C33:0D	Shift too short counter	RO	0x0000 (0 _{dec})
	1C33:20	Sync error	RO	0x00 (0 _{dec})
6000:0 ▶ 48	Subindex	AI Inputs Ch.1	RO	0x11 (17 _{dec})
	6000:07	Error	RO	0x00 (0 _{dec})
	6000:0F	TxPDO State	RO	0x00 (0 _{dec})
	6000:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6000:11	Value	RO	0x0000 (0 _{dec})
6010:0 ▶ 48	Subindex	AI Inputs Ch.2	RO	0x11 (17 _{dec})
	6010:07	Error	RO	0x00 (0 _{dec})
	6010:0F	TxPDO State	RO	0x00 (0 _{dec})
	6010:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6010:11	Value	RO	0x0000 (0 _{dec})
6020:0 ▶ 48	Subindex	AI Inputs Ch.3	RO	0x11 (17 _{dec})
	6020:07	Error	RO	0x00 (0 _{dec})
	6020:0F	TxPDO State	RO	0x00 (0 _{dec})
	6020:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6020:11	Value	RO	0x0000 (0 _{dec})
6030:0 ▶ 48	Subindex	AI Inputs Ch.4	RO	0x11 (17 _{dec})
	6030:07	Error	RO	0x00 (0 _{dec})
	6030:0F	TxPDO State	RO	0x00 (0 _{dec})
	6030:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6030:11	Value	RO	0x0000 (0 _{dec})
6040:0 ▶ 48	Subindex	AI Inputs Ch.5	RO	0x11 (17 _{dec})
	6040:07	Error	RO	0x00 (0 _{dec})
	6040:0F	TxPDO State	RO	0x00 (0 _{dec})

Index (hex)		Name	Flags	Default value
	6040:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6040:11	Value	RO	0x0000 (0 _{dec})
6050:0 [► 48]	Subindex	AI Inputs Ch.6	RO	0x11 (17 _{dec})
	6050:07	Error	RO	0x00 (0 _{dec})
	6050:0F	TxPDO State	RO	0x00 (0 _{dec})
	6050:10	TxPDO Toggle	RO	0x00 (0 _{dec})
	6050:11	Value	RO	0x0000 (0 _{dec})
8000:0 [► 40]	Subindex	AI Settings Ch.1	RW	0x1A (26 _{dec})
	8000:06	Enable filter	RW	0x00 (0 _{dec})
	8000:15	Filter settings	RW	0x0002 (2 _{dec})
	8000:19	Range	RW	0x0000 (0 _{dec})
	8000:1A	Presentation	RW	0x0001 (1 _{dec})
8010:0 [► 40]	Subindex	AI Settings Ch.2	RW	0x1A (26 _{dec})
	8010:06	Enable filter	RW	0x00 (0 _{dec})
	8010:15	Filter settings	RW	0x0002 (2 _{dec})
	8010:19	Range	RW	0x0000 (0 _{dec})
	8010:1A	Presentation	RW	0x0001 (1 _{dec})
8020:0 [► 41]	Subindex	AI Settings Ch.3	RW	0x1A (26 _{dec})
	8020:06	Enable filter	RW	0x00 (0 _{dec})
	8020:15	Filter settings	RW	0x0002 (2 _{dec})
	8020:19	Range	RW	0x0000 (0 _{dec})
	8020:1A	Presentation	RW	0x0001 (1 _{dec})
8030:0 [► 41]	Subindex	AI Settings Ch.4	RW	0x1A (26 _{dec})
	8030:06	Enable filter	RW	0x00 (0 _{dec})
	8030:15	Filter settings	RW	0x0002 (2 _{dec})
	8030:19	Range	RW	0x0000 (0 _{dec})
	8030:1A	Presentation	RW	0x0001 (1 _{dec})
8040:0 [► 42]	Subindex	AI Settings Ch.5	RW	0x1A (26 _{dec})
	8040:06	Enable filter	RW	0x00 (0 _{dec})
	8040:15	Filter settings	RW	0x0002 (2 _{dec})
	8040:19	Range	RW	0x0000 (0 _{dec})
	8040:1A	Presentation	RW	0x0001 (1 _{dec})
8050:0 [► 42]	Subindex	AI Settings Ch.6	RW	0x1A (26 _{dec})
	8050:06	Enable filter	RW	0x00 (0 _{dec})
	8050:15	Filter settings	RW	0x0002 (2 _{dec})
	8050:19	Range	RW	0x0000 (0 _{dec})
	8050:1A	Presentation	RW	0x0001 (1 _{dec})
8060:0 [► 43] (FW01)	Subindex	SAI Settings	RW	0x1D (29 _{dec})
	8060:0D	Filter sampling rate	RW	0x0002 (2 _{dec})
	8060:11	Range	RW	0x0000 (0 _{dec})
	8060:1D	Presentation	RW	0x0001 (1 _{dec})
F000:0 [► 49]	Subindex	Modular device profile	RO	0x02 (2 _{dec})
	F000:01	Module index distance	RO	0x0010 (16 _{dec})
	F000:02	Maximum number of modules	RO	0x0002 (2 _{dec})
F008 [► 49]		Code word	RW	0x00000000 (0 _{dec})
F010:0 [► 49]	Subindex	Module list	RW	0x02 (2 _{dec})
	F010:01	SubIndex 001	RW	0x00000258 (600 _{dec})
	F010:02	SubIndex 002	RW	0x00000258 (600 _{dec})
F800:0 [► 43] (from FW02)	Subindex	SAI Settings	RW	0x1D (29 _{dec})
	F800:0D	Filter sampling rate	RW	0x0002 (2 _{dec})
	F800:11	Range	RW	0x0000 (0 _{dec})
	F800:1D	Presentation	RW	0x0001 (1 _{dec})

Key

Flags:

RO (Read Only): This object can only be read.
 RW (Read/Write): This object can be read and written to.

6.2 Object description and parameterization



Parameterization

You can parameterize the box via the "CoE - Online" tab in TwinCAT.



EtherCAT XML Device Description

The presentation matches that of the EtherCAT XML Device Description.

Recommendation: download the latest XML file from <https://www.beckhoff.com> and install it according to the installation instructions.

Introduction

The CoE overview contains objects for different intended applications:

- Objects required for parameterization [► 39] during commissioning
- Objects for indicating internal settings [► 44] (may be fixed)
- Further profile-specific objects [► 48] indicating inputs, outputs and status information

The following section first describes the objects required for normal operation, followed by a complete overview of missing objects.

Objects to be parameterized during commissioning

Index 1011 Restore default parameters

Index (hex)	Name	Meaning	Data type	Flags	Default
1011:0	Restore default parameters	Restore default settings	UINT8	RO	0x01 (1 _{dec})
1011:01	SubIndex 001	If this object is set to " 0x64616F6C " in the Set Value Dialog, all backup objects are reset to their delivery state.	UINT32	RW	0x00000000 (0 _{dec})

Index 8000 AI Settings Ch.1

Index (hex)	Name	Meaning	Data type	Flags	Default
8000:0	AI Settings Ch.1		UINT8	RO	0x1A (26 _{dec})
8000:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8000:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8000:19	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8000:1A	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8010 AI Settings Ch.2

Index (hex)	Name	Meaning	Data type	Flags	Default
8010:0	AI Settings Ch.2		UINT8	RO	0x1A (26 _{dec})
8010:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8010:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8010:19	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8010:1A	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8020 AI Settings Ch.3

Index (hex)	Name	Meaning	Data type	Flags	Default
8020:0	AI Settings Ch.3		UINT8	RO	0x1A (26 _{dec})
8020:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8020:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8020:19	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8020:1A	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8030 AI Settings Ch.4

Index (hex)	Name	Meaning	Data type	Flags	Default
8030:0	AI Settings Ch.4		UINT8	RO	0x11 (21 _{dec})
8030:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8030:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8030:19	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8030:1A	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8040 AI Settings Ch.5

Index (hex)	Name	Meaning	Data type	Flags	Default
8040:0	AI Settings Ch.5		UINT8	RO	0x1A (26 _{dec})
8040:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8040:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8040:19	Range	Setting the measuring range: • 0_{dec}: +-2G • 1_{dec}: +-4G • 2_{dec}: +-8G • 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8040:1A	Presentation	Representation of the data • 0_{dec}: Raw values • 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8050 AI Settings Ch.6

Index (hex)	Name	Meaning	Data type	Flags	Default
8050:0	AI Settings Ch.6		UINT8	RO	0x1A (26 _{dec})
8050:06	Enable filter	Activates the filter.	BOOLEAN	RW	0x00 (0 _{dec})
8050:15	Filter settings	This object determines the filter settings of all channels of the module when it is activated via <i>Enable filter</i> index 0x80n0:06.	UINT16	RW	0x0002 (2 _{dec})
		0 FIR			
		2 IIR1			
		3 IIR2			
		4 IIR3			
		5 IIR4			
		6 IIR5			
		7 IIR6			
		8 IIR7			
		9 IIR8			
8050:19	Range	Setting the measuring range: • 0_{dec}: +-2G • 1_{dec}: +-4G • 2_{dec}: +-8G • 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8050:1A	Presentation	Representation of the data • 0_{dec}: Raw values • 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index 8060 SAI Settings (Firmware 01)

The object with index 8060 is invisible in the object directory from Firmware 02. However, it can still be read and written via SDO access. This ensures backward compatibility with PLC programs that were written prior to the release of Firmware 02.

The content of index 8060 is mirrored in [index F800 \[► 43\]](#) from Firmware 02.

Index (hex)	Name	Meaning	Data type	Flags	Default
8060:0	SAI Settings		UINT8	RO	0x1D (29 _{dec})
8060:0D	Filter sampling rate	Selection of the internal sampling rate: 0_{dec}: 200 Hz 1_{dec}: 500 Hz 2_{dec}: 1000 Hz 3_{dec}: 2500 Hz 4_{dec}: 5000 Hz - The sensor resolution is reduced to 8-bit if the rate is increased to 2500 Hz or 5000 Hz.	UINT16	RW	0x0002 (2 _{dec})
8060:11	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G	UINT16	RW	0x0000 (0 _{dec})
8060:1D	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG)	UINT16	RW	0x0001 (1 _{dec})

Index F800 SAI Settings (from Firmware 02)

Index (hex)	Name	Meaning	Data type	Flags	Default
F800:0	SAI Settings		UINT8	RO	0x1D (29 _{dec})
F800:0D	Filter sampling rate	Selection of the internal sampling rate: 0_{dec}: 200 Hz 1_{dec}: 500 Hz 2_{dec}: 1000 Hz 3_{dec}: 2500 Hz 4_{dec}: 5000 Hz - The sensor resolution is reduced to 8-bit if the rate is increased to 2500 Hz or 5000 Hz.	UINT16	RW	0x0002 (2 _{dec})
F800:11	Range	Setting the measuring range: 0_{dec}: +-2G 1_{dec}: +-4G 2_{dec}: +-8G 3_{dec}: +-16G 255_{dec}: Channel setting: The measuring range is set individually for each channel via the indices 0x80n0:19.	UINT16	RW	0x0000 (0 _{dec})
F800:1D	Presentation	Representation of the data 0_{dec}: Raw values 1_{dec}: milli G (mG) 255_{dec}: Channel setting: The representation is set channel-wise via the indices 0x80n0:1A.	UINT16	RW	0x0001 (1 _{dec})

Additional objects**Standard objects (0x1000-0x1FFF)**

The standard objects have the same meaning for all EtherCAT slaves.

Index 1000 Device type

Index (hex)	Name	Meaning	Data type	Flags	Default
1000:0	Device type	Device type of the EtherCAT slave: The Lo-Word contains the CoE profile used (5001). The Hi-Word contains the module profile according to the modular device profile.	UINT32	RO	0x00001389 (5001 _{dec})

Index 1008 Device name

Index (hex)	Name	Meaning	Data type	Flags	Default
1008:0	Device name	Device name of the EtherCAT slave	STRING	RO	EP3752-0000

Index 1009 Hardware version

Index (hex)	Name	Meaning	Data type	Flags	Default
1009:0	Hardware version	Hardware version of the EtherCAT slave	STRING	RO	00

Index 100A Software Version

Index (hex)	Name	Meaning	Data type	Flags	Default
100A:0	Software version	Firmware version of the EtherCAT slave	STRING	RO	00

Index 1018 Identity

Index (hex)	Name	Meaning	Data type	Flags	Default
1018:0	Identity	Information for identifying the slave	UINT8	RO	0x04 (4 _{dec})
1018:01	Vendor ID	Vendor ID of the EtherCAT slave	UINT32	RO	0x00000002 (2 _{dec})
1018:02	Product code	Product code of the EtherCAT slave	UINT32	RO	0x0EA84052 (245907538 _{dec})
1018:03	Revision	Revision number of the EtherCAT slave; the Low Word (bit 0-15) indicates the special terminal number, the High Word (bit 16-31) refers to the device description	UINT32	RO	0x00100002 (1048578 _{dec})
1018:04	Serial number	Serial number of the EtherCAT slave; the Low Byte (bit 0-7) of the Low Word contains the year of production, the High Byte (bit 8-15) of the Low Word contains the week of production, the High Word (bit 16-31) is 0	UINT32	RO	0x00000000 (0 _{dec})

Index 10F0 Backup parameter handling

Index (hex)	Name	Meaning	Data type	Flags	Default
10F0:0	Backup parameter handling	Information for standardized loading and saving of backup entries	UINT8	RO	0x01 (1 _{dec})
10F0:01	Checksum	Checksum across all backup entries of the EtherCAT slave	UINT32	RO	0x00000000 (0 _{dec})

Index 1A00 AI TxPDO-Map Inputs Ch.1

Index (hex)	Name	Meaning	Data type	Flags	Default
1A00:0	AI TxPDO-Map Inputs Ch.1	PDO Mapping TxPDO 1	UINT8	RO	0x06 (6 _{dec})
1A00:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A00:02	SubIndex 002	2. PDO Mapping entry (object 0x6000 (AI Inputs Ch.1), entry 0x07 (Error))	UINT32	RO	0x6000:07, 1
1A00:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0000:00, 7
1A00:04	SubIndex 004	4. PDO Mapping entry (object 0x6000 (AI Inputs Ch.1), entry 0x0F (TxPDO State))	UINT32	RO	0x6000:0F, 1
1A00:05	SubIndex 005	5. PDO Mapping entry (object 0x6000 (AI Inputs Ch.1), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6000:10, 1
1A00:06	SubIndex 006	6. PDO Mapping entry (object 0x6000 (AI Inputs Ch.1), entry 0x11 (Value))	UINT32	RO	0x6000:11, 16

Index 1A01 AI TxPDO-Map Inputs Ch.2

Index (hex)	Name	Meaning	Data type	Flags	Default
1A01:0	AI TxPDO-Map Inputs Ch.1	PDO Mapping TxPDO 2	UINT8	RO	0x06 (6 _{dec})
1A01:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A01:02	SubIndex 002	2. PDO Mapping entry (object 0x6010 (AI Inputs Ch.2), entry 0x07 (Error))	UINT32	RO	0x6010:07, 1
1A01:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0010:00, 7
1A01:04	SubIndex 004	4. PDO Mapping entry (object 0x6010 (AI Inputs Ch.2), entry 0x0F (TxPDO State))	UINT32	RO	0x6010:0F, 1
1A01:05	SubIndex 005	5. PDO Mapping entry (object 0x6010 (AI Inputs Ch.2), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6010:10, 1
1A01:06	SubIndex 006	6. PDO Mapping entry (object 0x6010 (AI Inputs Ch.2), entry 0x11 (Value))	UINT32	RO	0x6010:11, 16

Index 1A02 AI TxPDO-Map Inputs Ch.3

Index (hex)	Name	Meaning	Data type	Flags	Default
1A02:0	AI TxPDO-Map Inputs Ch.3	PDO Mapping TxPDO 3	UINT8	RO	0x06 (6 _{dec})
1A02:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A02:02	SubIndex 002	2. PDO Mapping entry (object 0x6020 (AI Inputs Ch.3), entry 0x07 (Error))	UINT32	RO	0x6020:07, 1
1A02:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0000:00, 7
1A02:04	SubIndex 004	4. PDO Mapping entry (object 0x6020 (AI Inputs Ch.3), entry 0x0F (TxPDO State))	UINT32	RO	0x6020:0F, 1
1A02:05	SubIndex 005	5. PDO Mapping entry (object 0x6020 (AI Inputs Ch.3), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6020:10, 1
1A02:06	SubIndex 006	6. PDO Mapping entry (object 0x6020 (AI Inputs Ch.3), entry 0x11 (Value))	UINT32	RO	0x6020:11, 16

Index 1A03 AI TxPDO-Map Inputs Ch.4

Index (hex)	Name	Meaning	Data type	Flags	Default
1A03:0	AI TxPDO-Map Inputs Ch.4	PDO Mapping TxPDO 4	UINT8	RO	0x06 (6 _{dec})
1A03:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A03:02	SubIndex 002	2. PDO Mapping entry (object 0x6030 (AI Inputs Ch.4), entry 0x07 (Error))	UINT32	RO	0x6030:07, 1
1A03:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0000:00, 7
1A03:04	SubIndex 004	4. PDO Mapping entry (object 0x6030 (AI Inputs Ch.4), entry 0x0F (TxPDO State))	UINT32	RO	0x6030:0F, 1
1A03:05	SubIndex 005	5. PDO Mapping entry (object 0x6030 (AI Inputs Ch.4), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6030:10, 1
1A03:06	SubIndex 006	6. PDO Mapping entry (object 0x6030 (AI Inputs Ch.4), entry 0x11 (Value))	UINT32	RO	0x6030:11, 16

Index 1A04 AI TxPDO-Map Inputs Ch.5

Index (hex)	Name	Meaning	Data type	Flags	Default
1A04:0	AI TxPDO-Map Inputs Ch.5	PDO Mapping TxPDO 5	UINT8	RO	0x06 (6 _{dec})
1A04:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A04:02	SubIndex 002	2. PDO Mapping entry (object 0x6040 (AI Inputs Ch.5), entry 0x07 (Error))	UINT32	RO	0x6040:07, 1
1A04:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0000:00, 7
1A04:04	SubIndex 004	4. PDO Mapping entry (object 0x6040 (AI Inputs Ch.5), entry 0x0F (TxPDO State))	UINT32	RO	0x6040:0F, 1
1A04:05	SubIndex 005	5. PDO Mapping entry (object 0x6040 (AI Inputs Ch.5), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6040:10, 1
1A04:06	SubIndex 006	6. PDO Mapping entry (object 0x6040 (AI Inputs Ch.5), entry 0x11 (Value))	UINT32	RO	0x6040:11, 16

Index 1A05 AI TxPDO-Map Inputs Ch.6

Index (hex)	Name	Meaning	Data type	Flags	Default
1A05:0	AI TxPDO-Map Inputs Ch.6	PDO Mapping TxPDO 5	UINT8	RO	0x06 (6 _{dec})
1A05:01	SubIndex 001	1. PDO Mapping entry (6 bit align)	UINT32	RO	0x0000:00, 6
1A05:02	SubIndex 002	2. PDO Mapping entry (object 0x6050 (AI Inputs Ch.6), entry 0x07 (Error))	UINT32	RO	0x6050:07, 1
1A05:03	SubIndex 003	3. PDO Mapping entry (7 bit align)	UINT32	RO	0x0000:00, 7
1A05:04	SubIndex 004	4. PDO Mapping entry (object 0x6050 (AI Inputs Ch.6), entry 0x0F (TxPDO State))	UINT32	RO	0x6050:0F, 1
1A05:05	SubIndex 005	5. PDO Mapping entry (object 0x6050 (AI Inputs Ch.6), entry 0x10 (TxPDO Toggle))	UINT32	RO	0x6050:10, 1
1A05:06	SubIndex 006	6. PDO Mapping entry (object 0x6050 (AI Inputs Ch.6), entry 0x11 (Value))	UINT32	RO	0x6050:11, 16

Index 1C00 Sync manager type

Index (hex)	Name	Meaning	Data type	Flags	Default
1C00:0	Sync manager type	Using the Sync Managers	UINT8	RO	0x04 (4 _{dec})
1C00:01	SubIndex 001	Sync-Manager Type Channel 1: Mailbox Write	UINT8	RO	0x01 (1 _{dec})
1C00:02	SubIndex 002	Sync-Manager Type Channel 2: Mailbox Read	UINT8	RO	0x02 (2 _{dec})
1C00:03	SubIndex 003	Sync-Manager Type Channel 3: Process Data Write (Outputs)	UINT8	RO	0x03 (3 _{dec})
1C00:04	SubIndex 004	Sync-Manager Type Channel 4: Process Data Read (Inputs)	UINT8	RO	0x04 (4 _{dec})

Index 1C12 RxPDO assign

Index (hex)	Name	Meaning	Data type	Flags	Default
1C12:0	RxPDO assign	PDO Assign Outputs	UINT8	RW	0x00 (0 _{dec})

Index 1C13 TxPDO assign

Index (hex)	Name	Meaning	Data type	Flags	Default
1C13:0	TxPDO assign	PDO Assign Inputs	UINT8	RW	0x04 (4 _{dec})
1C13:01	Subindex 001	1. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A00 (6656 _{dec})
1C13:02	Subindex 002	2. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A01 (6657 _{dec})
1C13:03	Subindex 003	3. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A02 (6658 _{dec})
1C13:04	Subindex 004	4. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A03 (6659 _{dec})
1C13:05	Subindex 005	5. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A04 (6660 _{dec})
1C13:06	Subindex 006	6. allocated TxPDO (contains the index of the associated TxPDO mapping object)	UINT16	RW	0x1A06 (6662 _{dec})

Index 1C33 SM input parameter

Index (hex)	Name	Meaning	Data type	Flags	Default
1C33:0	SM input parameter	Synchronization parameters for the inputs	UINT8	RO	0x20 (32 _{dec})
1C33:01	Sync mode	Current synchronization mode: 0: Free Run 1: Synchron with SM 3 Event (no outputs available) 2: DC - Synchron with SYNC0 Event 3: DC - Synchron with SYNC1 Event 34: Synchron with SM 2 Event (outputs available)	UINT16	RW	0x0022 (34 _{dec})
1C33:02	Cycle time	Cycle time (in ns): - Free Run: Cycle time of the local timer - Synchron with SM 2 Event: Master cycle time - DC mode: SYNC0/SYNC1 Cycle Time	UINT32	RW	0x000F4240 (1000000 _{dec})
1C33:03	Shift time	Time between SYNC0 event and reading of the inputs (in ns, only DC mode)	UINT32	RO	0x00000000 (0 _{dec})
1C33:04	Sync modes supported	Supported synchronization modes: - Bit 0: free run is supported - Bit 1: Synchron with SM 2 Event is supported (outputs available) - Bit 1: Synchron with SM 3 Event is supported (no outputs available) - Bit 2-3 = 01: DC mode is supported - Bit 4-5 = 01: Input Shift through local event (outputs available) - Bit 4-5 = 10: Input Shift with SYNC1 event (no outputs available) - Bit 14 = 1: dynamic times (measurement through writing of 0x1C32:08 or 0x1C33:08)	UINT16	RO	0x0003 (3 _{dec})
1C33:05	Minimum cycle time	Minimum cycle time supported (in ns)	UINT32	RO	0x0003D040 (20000 _{dec})
1C33:06	Calc and copy time	Time between reading of the inputs and availability of the inputs for the master (in ns, only DC mode)	UINT32	RO	0x00000000 (0 _{dec})
1C33:07	Minimum delay time		UINT32	RO	0x00000000 (0 _{dec})
1C33:08	Command	With this entry the real required process data provision time can be measured. 0: Measurement of the local cycle time is stopped 1: Measurement of the local cycle time is started The entries 0x1C33:03, 0x1C33:06, 0x1C33:09 are updated with the maximum measured values. For a subsequent measurement the measured values are reset	UINT16	RW	0x0000 (0 _{dec})
1C33:09	Maximum Delay time	Time between SYNC1 event and reading of the inputs (in ns, only DC mode)	UINT32	RO	0x00000000 (0 _{dec})
1C33:0B	SM event missed counter	Number of missed SM events in OPERATIONAL (DC mode only)	UINT16	RO	0x0000 (0 _{dec})
1C33:0C	Cycle exceeded counter	Number of occasions the cycle time was exceeded in OPERATIONAL (cycle was not completed in time or the next cycle began too early)	UINT16	RO	0x0000 (0 _{dec})
1C33:0D	Shift too short counter	Number of occasions that the interval between SYNC0 and SYNC1 event was too short (DC mode only)	UINT16	RO	0x0000 (0 _{dec})
1C33:20	Sync error	The synchronization was not correct in the last cycle (outputs were output too late; DC mode only)	BOOLEAN	RO	0x00 (0 _{dec})

Profile-specific objects (0x6000-0xFFFF)

The profile-specific objects have the same meaning for all EtherCAT slaves that support the profile 5001.

Index 6000 AI Inputs Ch.1

Index (hex)	Name	Meaning	Data type	Flags	Default
6000:0	AI Inputs Ch.1		UINT8	RO	0x11 (17 _{dec})
6000:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6000:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6000:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6000:11	Value		INT16	RO	0x0000 (0 _{dec})

Index 6010 AI Inputs Ch.2

Index (hex)	Name	Meaning	Data type	Flags	Default
6010:0	AI Inputs Ch.2		UINT8	RO	0x11 (17 _{dec})
6010:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6010:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6010:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6010:11	Value		INT16	RO	0x0000 (0 _{dec})

Index 6020 AI Inputs Ch.3

Index (hex)	Name	Meaning	Data type	Flags	Default
6020:0	AI Inputs Ch.3		UINT8	RO	0x11 (17 _{dec})
6020:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6020:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6020:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6020:11	Value		INT16	RO	0x0000 (0 _{dec})

Index 6030 AI Inputs Ch.4

Index (hex)	Name	Meaning	Data type	Flags	Default
6030:0	AI Inputs Ch.4		UINT8	RO	0x11 (17 _{dec})
6030:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6030:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6030:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6030:11	Value		INT16	RO	0x0000 (0 _{dec})

Index 6040 AI Inputs Ch.5

Index (hex)	Name	Meaning	Data type	Flags	Default
6040:0	AI Inputs Ch.5		UINT8	RO	0x11 (17 _{dec})
6040:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6040:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6040:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6040:11	Value		INT16	RO	0x0000 (0 _{dec})

Index 6050 AI Inputs Ch.6

Index (hex)	Name	Meaning	Data type	Flags	Default
6050:0	AI Inputs Ch.6		UINT8	RO	0x11 (17 _{dec})
6050:07	Error		BOOLEAN	RO	0x00 (0 _{dec})
6050:0F	TxPDO State		BOOLEAN	RO	0x00 (0 _{dec})
6050:10	TxPDO Toggle		BOOLEAN	RO	0x00 (0 _{dec})
6050:11	Value		INT16	RO	0x0000 (0 _{dec})

Index F000 Modular device profile

Index (hex)	Name	Meaning	Data type	Flags	Default
F000:0	Modular device profile	General information for the modular device profile	UINT8	RO	0x02 (2 _{dec})
F000:01	Module index distance	Index distance of the objects of the individual channels	UINT16	RO	0x0010 (16 _{dec})
F000:02	Maximum number of modules	Number of channels	UINT16	RO	0x0002 (2 _{dec})

Index F008 Code word

Index (hex)	Name	Meaning	Data type	Flags	Default
F008:0	Code word		UINT32	RW	0x00000000 (0 _{dec})

Index F010 Module list

Index (hex)	Name	Meaning	Data type	Flags	Default
F010:0	Module list		UINT8	RW	0x02 (2 _{dec})
F010:01	SubIndex 001		UINT32	RW	0x00000258 (600 _{dec})
F010:02	SubIndex 002		UINT32	RW	0x00000258 (600 _{dec})

7 Appendix

7.1 General operating conditions

Protection rating according to IP code

The degrees of protection are defined and divided into different classes in the IEC 60529 standard (EN 60529). Degrees of protection are designated by the letters "IP" and two numerals: **IPxy**

- Numeral x: Dust protection and contact protection
- Numeral y: Protection against water

x	Meaning
0	Not protected
1	Protected against access to dangerous parts with the back of the hand. Protected against solid foreign objects of 50 mm Ø
2	Protected against access to dangerous parts with a finger. Protected against solid foreign objects of 12.5 mm Ø
3	Protected against access to dangerous parts with a tool. Protected against solid foreign objects of 2.5 mm Ø
4	Protected against access to dangerous parts with a wire. Protected against solid foreign objects of 1 mm Ø
5	Protection against access to dangerous parts with a wire. Dust-protected. Ingress of dust is not prevented completely, although the quantity of dust able to penetrate is limited to such an extent that the proper function of the device and safety are not impaired
6	Protection against access to dangerous parts with a wire. Dust-tight. No ingress of dust

y	Meaning
0	Not protected
1	Protection against vertically falling water drops
2	Protection against vertically falling water drops when enclosure tilted up to 15°
3	Protection against spraying water. Water sprayed at an angle of up to 60° on either side of the vertical shall have no harmful effects
4	Protection against splashing water. Water splashed against the enclosure from any direction shall have no harmful effects
5	Protection against water jets.
6	Protection against powerful water jets.
7	Protected against the effects of temporary immersion in water. Ingress of water in quantities causing harmful effects shall not be possible when the enclosure is immersed in water at a depth of 1 m for 30 minutes

Chemical resistance

The resistance refers to the housing of the IP67 modules and the metal parts used. In the table below you will find some typical resistances.

Type	Resistance
Water vapor	unstable at temperatures > 100 °C
Sodium hydroxide solution (ph value > 12)	stable at room temperature unstable > 40 °C
Acetic acid	unstable
Argon (technically pure)	stable

Key

- resistant: Lifetime several months
- non inherently resistant: Lifetime several weeks
- not resistant: Lifetime several hours resp. early decomposition

7.2 Accessories

Mounting

Ordering information	Description	Link
ZS5300-0011	Mounting rail	Data sheet

Cables

A complete overview of pre-assembled cables can be found on the Beckhoff website: [Link](#).

Ordering information	Description	Link
ZK1090-3xxx-xxxx	EtherCAT cable M8, green	Website
ZK1093-3xxx-xxxx	EtherCAT cable M8, yellow	Website
ZK2020-3xxx-xxxx	Power cable M8, 4-pin	Website

Labeling material, protective caps

Ordering information	Description	
ZS5000-0010	Blanking plug for M8 sockets, IP67 (50 pieces)	Website
ZS5100-0000	Inscription labels, unprinted, 4 strips of 10	Data sheet
ZS5000-xxxx	Printed inscription labels on enquiry	n/a

Tools

Ordering information	Description	Link
ZB8801-0000	Torque wrench for plugs, 0.4...1.0 Nm	Website
ZB8801-0001	Torque cable key for M8/wrench size 9 for ZB8801-0000	Website



Further accessories

You can find further accessories at <https://www.beckhoff.com/accessories>.

7.3 Version identification of EtherCAT devices

7.3.1 General notes on marking

Name

A Beckhoff EtherCAT device has a 14-digit technical designation consisting of

- Family key
- Type
- Version
- Revision

Example	Family	Type	Version	Revision
EL3314-0000-0016	EL Terminal 12 mm, fixed connection level	3314 4-channel thermocouple terminal	0000 basic type	0016
ES3602-0010-0017	ES Terminal 12 mm, pluggable connection level	3602 2-channel voltage measurement	0010 high-precision version	0017
CU2008-0000-0000	CU device	2008 8-port Fast Ethernet switch	0000 basic type	0000

Notes

- The elements stated above result in the **technical designation**. EL3314-0000-0016 is used in the example below.
- EL3314-0000 is the order identifier, for “-0000” usually abbreviated to EL3314. “-0016” is the EtherCAT revision.
- The **order identifier** is composed of
 - family key (EL, EP, CU, ES, KL, CX, etc.)
 - type (3314)
 - version (0000)
- The **revision** -0016 reflects the technical progress such as feature enhancement with regard to EtherCAT communication and is managed by Beckhoff.
In principle, a device with a higher revision can replace a device with a lower revision, unless otherwise specified, e.g. in the documentation.
There is usually a description (ESI, EtherCAT Slave Information) in the form of an XML file which is associated and synonymous with each revision, and this is available for download from the Beckhoff website.
Since January 2014, the revision has been marked on the outside of the IP20 terminals; see Fig. *“EL2872 with revision 0022 and serial number 01200815.”*
- The type, version, and revision are read as decimal numbers, even if they are technically saved in hexadecimal.

7.3.2 Version identification of IP67 modules

The serial number/date code for Beckhoff IO devices is usually the 8-digit number printed on the device or on a sticker. The serial number indicates the configuration in delivery state and therefore refers to a whole production batch, without distinguishing the individual modules within a batch.

Structure of the serial number: **KK YY FF HH**

KK – week of production (calendar week)

YY – year of production

FF – firmware version

HH – hardware version

Example with serial number 12 06 3A 02:

12 – week of production 12

06 – year of production 2006

3A – firmware version 3A

02 – hardware version 02




Fig. 9: EP1258-00001 IP67 EtherCAT Box with batch number/DateCode 22090101 and unique serial number 158102

7.3.3 Beckhoff Identification Code (BIC)

The Beckhoff Identification Code (BIC) is increasingly being applied to Beckhoff products to uniquely identify them. The BIC is represented as a Data Matrix code (DMC, code schema ECC200); its content is based on ANSI standard MH10.8.2-2016.




Fig. 10: BIC as a Data Matrix code (DMC, ECC200 code scheme)

The BIC is being introduced gradually across all product groups. Depending on the product, it can be found in the following locations:

- on the packaging unit
- directly on the product (if space suffices)
- on the packaging unit and the product

The BIC is machine-readable and contains information that can be used for handling and product management by the customer.

Each item of information is clearly identifiable with the data identifier (ANSI MH10.8.2-2016). The data identifier is followed by a character string. Both together have a maximum length stated by the following table. If the items of information are shorter, spaces are added.

The following information may be present; items 1 through 4 are always included, while the others depend on the product family's requirements:

Item no.	Type of information	Explanation	Data identifier	Number of characters including the data identifier	Example
1	Beckhoff order number	Beckhoff order number	1P	8	1P 072222
2	Beckhoff Traceability Number (BTN)	Unique serial number, see note below	SBTN	12	SBTN k4p562d7
3	Article description	Beckhoff article description, e.g. EL1008	1K	32	1KEL 1809
4	Quantity	Quantity in packaging unit, e.g. 1, 10, etc.	Q	6	Q1
5	Batch number	Optional: Year and week of production	2P	14	2P 401503180016
6	ID/serial number	Optional: Previous serial number system, e.g., for safety products or calibrated terminals	51S	12	51S 678294
7	Variant	Optional: Product variant number on the basis of standard products	30P	12	30P F971, 2*K183
...					

Beckhoff uses additional types of information and data identifiers for internal processes.

Structure of the BIC

Example of composite information consisting of items 1 through 4 and the example value mentioned above in item 6. The data identifiers are highlighted in bold:

1P072222**SBTN**k4p562d7**1KEL**1809 **Q1** **51S**678294

The same number as a DMC:



Fig. 11: Example DMC **1P**072222**SBTN**k4p562d7**1KEL**1809 **Q1** **51S**678294

BTN

An important component of the BIC is the Beckhoff Traceability Number (BTN, item no. 2). The BTN is a unique 8-character serial number that will replace all other serial number systems at Beckhoff in the future (e.g. batch designations on IO components, previous serial number circle for safety products, etc.). The BTN is also being introduced gradually, so it may not yet be coded in the BIC.

NOTICE

This information has been carefully prepared. However, the method described is constantly being refined. We reserve the right to revise and change procedures and documentation at any time and without notice. No claims for modification may be made on the basis of the data, diagrams, and descriptions in this documentation.

7.3.4 Electronic access to the BIC (eBIC)

Electronic BIC (eBIC)

The Beckhoff Identification Code (BIC) is applied to the outside of Beckhoff products in a visible place. If possible, it should also be electronically readable.

The interface that the product can be electronically addressed by is crucial for the electronic readout.


EtherCAT devices (IP20, IP67)

All Beckhoff EtherCAT devices have an ESI-EEPROM which contains the EtherCAT identity with the revision number. The EtherCAT slave information, also colloquially known as the ESI/XML configuration file for the EtherCAT master, is stored in it. See the corresponding chapter in the EtherCAT system manual ([Link](#)) for the relationships.

Beckhoff also writes the eBIC in the ESI-EEPROM. The eBIC was introduced into Beckhoff IO production (terminals, box modules) in 2020; as of 2023, implementation is largely complete.

The user can electronically access the eBIC (if present) as follows:

- With all EtherCAT devices, the EtherCAT master (TwinCAT) can read the eBIC from the ESI-EEPROM:
 - From TwinCAT 3.1 build 4024.11, the eBIC can be displayed in the online view.
 - To do this, check the “Show Beckhoff Identification Code (BIC)” checkbox under EtherCAT → Advanced Settings → Diagnostics:



- The BTN and its contents are then displayed:

No	Addr	Name	State	CRC	Fw	Hw	Production Data	ItemNo	BTN	Description	Quantity	BatchNo	SerialNo
1	1001	Term 1 (EK1100)	OP	0, 0	0	0	—	—	—	—	—	—	—
2	1002	Term 2 (EL1018)	OP	0, 0	0	0	2020 KW36 Fr	072222	k4p562d7	EL1809	1	—	678294
3	1003	Term 3 (EL3204)	OP	0, 0	7	6	2012 KW24 Sa	—	—	—	—	—	—
4	1004	Term 4 (EL2004)	OP	0, 0	0	0	—	072223	k4p562d7	EL2004	1	—	678295
5	1005	Term 5 (EL1008)	OP	0, 0	0	0	—	—	—	—	—	—	—
6	1006	Term 6 (EL2008)	OP	0, 0	0	12	2014 KW14 Mo	—	—	—	—	—	—
7	1007	Term 7 (EK1110)	OP	0	1	8	2012 KW25 Mo	—	—	—	—	—	—

- Note: As shown in the figure, the production data HW version, FW version, and production date, which have been programmed since 2012, can also be displayed with “Show production info”.
- Access from the PLC: From TwinCAT 3.1. build 4024.24, the functions *FB_EcReadBIC* and *FB_EcReadBTN* for reading into the PLC are available in the Tc2_EtherCAT library from v3.3.19.0.
- EtherCAT devices with a CoE directory may also have the object 0x10E2:01 to display their own eBIC, which can also be easily accessed by the PLC:

- The device must be in PREOP/SAFEOP/OP for access

Index	Name	Flags	Value
1000	Device type	RO	0x015E1389 (22942601)
1008	Device name	RO	ELM3704-0000
1009	Hardware version	RO	00
100A	Software version	RO	01
100B	Bootloader version	RO	J0.1.27.0
+ 1011:0	Restore default parameters	RO	> 1 <
+ 1018:0	Identity	RO	> 4 <
- 10E2:0	Manufacturer-specific Identification C...	RO	> 1 <
- 10E2:01	SubIndex 001	RO	1P158442SBTN0008jekp1KELM3704 Q1 2P482001000016
+ 10F0:0	Backup parameter handling	RO	> 1 <
+ 10F3:0	Diagnosis History	RO	> 21 <
- 10F8	Actual Time Stamp	RO	0x170bfb277e

- The object 0x10E2 will be preferentially introduced into stock products in the course of necessary firmware revision.
- From TwinCAT 3.1. build 4024.24, the functions *FB_EcCoEReadBIC* and *FB_EcCoEReadBTN* for reading into the PLC are available in the Tc2_EtherCAT library from v3.3.19.0
- The following auxiliary functions are available for processing the BIC/BTN data in the PLC in *Tc2_Uilities* as of TwinCAT 3.1 build 4024.24
 - *F_SplitBIC*: The function splits the BIC sBICValue into its components using known identifiers and returns the recognized substrings in the ST_SplittedBIC structure as a return value
 - *BIC_TO_BTN*: The function extracts the BTN from the BIC and returns it as a return value
- Note: If there is further electronic processing, the BTN is to be handled as a string(8); the identifier "SBTN" is not part of the BTN.
- On the technical background:
The new BIC information is written as an additional category in the ESI-EEPROM during device production. The structure of the ESI content is largely dictated by the ETG specifications, therefore the additional vendor-specific content is stored using a category in accordance with the ETG.2010. ID 03 tells all EtherCAT masters that they may not overwrite these data in the event of an update or restore the data after an ESI update.
The structure follows the content of the BIC, see here. The EEPROM therefore requires approx. 50... 200 bytes of memory.
- Special cases
 - In a hierarchical configuration of multiple ESCs (EtherCAT Slave Controllers) within a single device, only the top-level ESC carries the eBIC information.
 - If multiple non-hierarchically arranged ESCs are installed in a device, all ESCs carry the eBIC information.
 - If the device consists of several sub-devices which each have their own identity, but only the top-level device is accessible via EtherCAT, the eBIC of that ESC is located in the CoE object directory 0x10E2:01 and the eBICs of the sub-devices follow in 0x10E2:nn.

7.4 Support and Service

Beckhoff Support and Service provides assistance with questions regarding Beckhoff products and system solutions, as well as with their planning, commissioning, and operation.

Beckhoff subsidiaries and representative offices

Please contact your Beckhoff subsidiary or your representative office for local support and service for Beckhoff products. You can find the addresses of Beckhoff subsidiaries and representative offices at: www.beckhoff.com/worldwide.

For Beckhoff products and technologies, we offer [Training programs](#), [tutorials](#), and [webinars](#).

Beckhoff Support

Beckhoff Support provides assistance with technical questions regarding the use, planning, programming, and commissioning of Beckhoff products.

☎ Hotline: +49 5246 963-157
✉ Email: support@beckhoff.com, [Support form](#)
Web page: www.beckhoff.com/support

Beckhoff Service

Our service specialists are here to assist you with any questions you may have regarding after-sales service processes, such as replacement parts, repairs, etc.

☎ Hotline: +49 5246 963-460
✉ Email: service@beckhoff.com, [Service form](#)
Web page: www.beckhoff.com/service

Download finder

The [Download finder](#) serves as a central source for downloadable documents and files related to Beckhoff products, such as application reports, technical documentation, drawings, and configuration files.

Beckhoff Information System

The [Beckhoff Information System](#) is the central online documentation resource for Beckhoff products and contains documentation on products and automation topics, as well as sample code.

Beckhoff Headquarters

Beckhoff Automation GmbH & Co. KG
Hülshorstweg 20
33415 Verl, Germany

☎ Phone: +49 5246 963-0
✉ Email: info@beckhoff.com
Web page: www.beckhoff.com

Trademark statements

Beckhoff®, ATRO®, EtherCAT®, EtherCAT G®, EtherCAT G10®, EtherCAT P®, MX-System®, Safety over EtherCAT®, TC/BSD®, TwinCAT®, TwinCAT/BSD®, TwinSAFE®, XFC®, XPlanar® and XTS® are registered and licensed trademarks of Beckhoff Automation GmbH.

More Information:
www.beckhoff.com/ep3752-0000

Beckhoff Automation GmbH & Co. KG
Hülshorstweg 20
33415 Verl
Germany
Phone: +49 5246 9630
info@beckhoff.com
www.beckhoff.com

